



November 28, 2022

Associate Director, Water Enforcement
U.S. Environmental Protection Agency
Region VI
1201 Elm Street, Suite 500
Mail Code ECADW
Dallas, Texas 75270-2102

Via USPS Certified Mail
7021 1970 0000 7631 8251
Via E-mail: Smalley.bryant@epa.gov

Re: City of Houston Wastewater Consent Decree
Civil Action No. 4:18-cv-03368
Monthly SSO Report – October 2022

Dear Mr. Smalley:

The City of Houston's monthly SSO summary report for October 2022 and corresponding SSO map are attached and provided in compliance with the requirements of Paragraph 61 of the City of Houston Wastewater Consent Decree.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

DocuSigned by:
Walid Samarneh
331FF7394B3D4AA...

Walid Samarneh
On behalf of Phillip Goodwin
Regulatory Compliance Director
Houston Public Works, City of Houston

Enc. October 2022 Monthly SSO Report; SSO Map for October 2022
cc via email: Nathaniel Douglas, DOJ (Nathaniel.douglas@usdoj.gov)
James Zimny, EPA (Zimny.james@epa.gov)
Alan Vaughn, EPA (vaughn.alan@epa.gov)
Phillip Ledbetter, Texas AG's Office (phillip.ledbetter@oag.texas.gov);
James Sallans, TCEQ (james.sallans@tceq.texas.gov)
Kristen Schlemmer, BCWK (kristen@bayoucitywaterkeeper.org)

PO Box 1562 | Houston, Texas 77251-1562 | HoustonPublicWorks.org

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
49502	WQ0010495076	14618 HEMPSTEAD RD	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Grease Blockage	10/1/2022	16:28	10/1/2022	16:29	0	Cleaned and Disinfected;Cleared City Clean Out
49503	WQ0010495119	11150 BEECHNUT ST	Storm Sewer (not contained)	Yes	0	City Cleanout	Grease Blockage	10/2/2022	9:43	10/2/2022	9:44	0	Cleared City Clean Out;Cleaned and Disinfected
49504	WQ0010495090	433 SEDGWICK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	10/2/2022	9:36	10/2/2022	9:37	0	Cleaned and Disinfected;Cleared City Clean Out
49505	WQ0010495122	16610 RUSTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	10/2/2022	9:58	10/2/2022	9:59	0	Set Bypass Pump
49511	WQ0010495002	5502 TELEPHONE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	10/2/2022	13:35	10/2/2022	13:36	0	Set Bypass Pump;Cleaned and Disinfected
49515	WQ0010495023	6220 WEDGEFIELD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	10/3/2022	9:22	10/3/2022	9:23	0	Cleaned and Disinfected;Set Bypass Pump
49517	WQ0010495076	10835 W LITTLE YORK RD	Storm Sewer (not contained)	Yes	729	Manhole	Grease Blockage	10/3/2022	9:34	10/3/2022	13:37	3	Cleaned and Disinfected;Cleared Main Line
49518	WQ0010495090	1511 SUMMER ST	Bayou/surface water/drainage ditch	Yes	440	Service Lateral	Collection system structural failure	10/3/2022	12:02	10/3/2022	15:42	2	Cleaned and Disinfected;Add Comments
49521	WQ0010495090	9501 LONG POINT RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	10/3/2022	14:28	10/3/2022	14:29	0	Cleaned and Disinfected;Cleared Main Line
49527	WQ0010495090	3623 KATY FWY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	318	Manhole	Grease Blockage	10/4/2022	10:17	10/4/2022	12:57	2	Cleared Main Line;Cleaned and Disinfected
49528	WQ0010495119	9525 S KIRKWOOD RD	Storm Sewer (not contained)	Yes	476	Manhole	Grease Blockage	10/4/2022	11:50	10/4/2022	15:48	2	Cleared Main Line;Cleaned and Disinfected
49534	WQ0010495146	1214 STONEHOLLOW DR	Storm Sewer (not contained)	Yes	214	Manhole	Grease Blockage	10/5/2022	9:10	10/5/2022	12:44	1	Cleaned and Disinfected;Cleared Main Line
49536	WQ0010495016	7402 SENFRONIA HILLS DR	Storm Sewer (not contained)	Yes	1680	Manhole	Collection system structural failure	10/5/2022	9:28	10/5/2022	18:48	3	Cleaned and Disinfected;Cleared Main Line;Set Bypass Pump



City of Houston - Houston Public Works
Monthly SSO Report
October 2022

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
49539	WQ0010495003	2052 SWIFT BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	10/5/2022	11:41	10/5/2022	11:42	0	Cleaned and Disinfected
49541	WQ0010495065	9630 INTERVALE ST	Storm Sewer (not contained)	Yes	0	Service Lateral	Grease Blockage	10/5/2022	12:15	10/6/2022	10:38	0	Cleaned and Disinfected;Cleared City Clean Out
49543	WQ0010495002	7914 WILMERDEAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	10/5/2022	11:01	10/5/2022	11:02	0	Cleaned and Disinfected
49544	WQ0010495016	10614 CHEEVES DR	Storm Sewer (not contained)	Yes	289	Manhole	Grease Blockage	10/5/2022	13:59	10/5/2022	18:48	1	Cleaned and Disinfected;Cleared Main Line
49547	WQ0010495111	10839 BELLAIRE BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	10/5/2022	16:55	10/5/2022	16:56	0	Cleared Service Lateral;Cleaned and Disinfected
49551	WQ0010495037	5427 ASHBROOK DR	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	10/5/2022	17:36	10/5/2022	17:37	0	Cleaned and Disinfected;Cleared Main Line
49554	WQ0010495077	12750 COULSON ST	Bayou/surface water/drainage ditch	Yes	0	Gravity Main	Rags/Wipes	10/6/2022	14:20	10/6/2022	15:00	0	Cleared Main Line;Cleaned and Disinfected
49556	WQ0010495090	6805 COHN ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Rags/Wipes	10/6/2022	14:40	10/6/2022	14:41	0	Cleared Service Lateral;Cleaned and Disinfected
49559	WQ0010495016	10318 CAXTON ST	Bayou/surface water/drainage ditch	Yes	0	Manhole	Collection system structural failure	10/6/2022	18:16	10/6/2022	18:17	0	Cleared Main Line;Cleaned and Disinfected;Post Warning Signs
49560	WQ0010495016	7459 WHEATLEY GARDENS DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	72	Manhole	Grease Blockage	10/5/2022	13:59	10/5/2022	18:48	0	Cleared Main Line;Cleaned and Disinfected
49561	WQ0010495002	3903 ERBY ST	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	10/7/2022	8:30	10/7/2022	8:31	0	Cleared Main Line;Cleaned and Disinfected
49577	WQ0010495003	1850 COLQUITT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	10/9/2022	11:07	10/9/2022	11:08	0	Cleaned and Disinfected;Cleared Service Lateral
49581	WQ0010495009	10225 SCOTT ST	Storm Sewer (not contained)	Yes	550	Manhole	Grease Blockage	10/10/2022	10:10	10/10/2022	12:00	5	Cleared Main Line;Cleaned and Disinfected
49585	WQ0010495076	6343 FRENCH CHATEAU DR	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	10/10/2022	13:00	10/10/2022	15:30	0	Cleaned and Disinfected;Cleared Main Line

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
October 2022

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
49589	WQ0010495009	10903 PANAY DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	528	Manhole	Grease Blockage	10/11/2022	8:33	10/11/2022	10:45	4	Cleaned and Disinfected;Cleared Main Line
49593	WQ0010495090	1211 SHELBY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	10	City Cleanout	Collection system structural failure	10/11/2022	12:30	10/11/2022	12:50	1	Set Bypass Pump
49595	WQ0010495037	8201 W BELLFORT AVE	Storm Sewer (not contained)	Yes	401	Manhole	Grease Blockage	10/11/2022	11:42	10/11/2022	18:23	1	Cleaned and Disinfected;Cleared Main Line
49599	WQ0010495090	117 N 79TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	272	Service Lateral	Collection system structural failure	10/11/2022	18:42	10/12/2022	12:50	0	Cleaned and Disinfected;Set Bypass Pump
49602	WQ0010495003	2930 LAZY LANE BLVD	Storm Sewer (not contained)	Yes	0	Manhole	Collection system structural failure	10/12/2022	11:22	10/12/2022	11:23	0	Cleaned and Disinfected;Cleared Main Line
49606	WQ0010495090	952 JUDIWAY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	10/12/2022	14:34	10/12/2022	14:35	0	Cleaned and Disinfected;Cleared Main Line
49607	WQ0010495090	3306 FOLGER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	10/12/2022	16:11	10/12/2022	16:12	0	Cleared Service Lateral;Cleaned and Disinfected
49608	WQ0010495090	5509 CAVALCADE ST	Storm Sewer (not contained)	Yes	50	Gravity Main	Grease Blockage	10/12/2022	9:50	10/12/2022	10:40	1	Cleared Main Line;Cleaned and Disinfected
49609	WQ0010495002	1206 HENNINGER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	10/13/2022	12:00	10/13/2022	12:01	0	Cleaned and Disinfected;Cleared City Clean Out
49610	WQ0010495119	3800 TANGLEWILDE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	10/13/2022	8:30	10/13/2022	8:31	0	Cleaned and Disinfected;Cleared City Clean Out
49614	WQ0010495077	459 CLAIRE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	10/13/2022	15:30	10/13/2022	16:50	0	Cleared Main Line;Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
October 2022

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
49624	WQ0010495016	9126 MADERA RD	Drainage Ditch	Yes	0	Service Lateral	Rags/Wipes	10/14/2022	11:59	10/14/2022	12:00	0	Cleaned and Disinfected;Cleared Service Lateral
49625	WQ0010495076	8709 BLANKENSHIP DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Rags/Wipes	10/14/2022	12:53	10/14/2022	12:54	0	Cleaned and Disinfected;Cleared Main Line
49630	WQ0010495037	6700 BELLAIRE BLVD	Storm Sewer (not contained)	Yes	374	Manhole	Grease Blockage	10/14/2022	14:44	10/14/2022	17:50	2	Cleaned and Disinfected;Cleared Main Line
49631	WQ0010495037	5810 FONDREN RD	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	10/14/2022	17:53	10/14/2022	17:54	0	Cleared Main Line;Cleaned and Disinfected
49632	WQ0010495003	12803 HARLESDEN LN	Storm Sewer (not contained)	Yes	1611	Manhole	Collection system temporary blockage	10/15/2022	8:02	10/15/2022	16:59	3	Cleared Main Line;Cleaned and Disinfected
49635	WQ0010495090	4801 JEWEL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	10/15/2022	13:05	10/15/2022	13:06	0	Cleaned and Disinfected;Cleared Main Line
49637	WQ0010495003	14430 MINETTA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	10/15/2022	14:27	10/15/2022	14:28	0	Cleared City Clean Out;Cleaned and Disinfected
49640	WQ0010495002	3602 OLD SPANISH TRL	Storm Sewer (not contained)	Yes	1468	Manhole	Grease Blockage	10/16/2022	9:30	10/17/2022	9:58	1	Cleaned and Disinfected;Cleared Main Line
49642	WQ0010495003	2219 DEVONSHIRE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	10/16/2022	10:08	10/16/2022	10:09	0	Set Bypass Pump;Cleaned and Disinfected
49648	WQ0010495111	10839 BELLAIRE BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	10/15/2022	20:00	10/15/2022	20:15	0	Cleared Service Lateral;Cleaned and Disinfected
49654	WQ0010495090	1001 HEIGHTS BLVD	Storm Sewer (not contained)	Yes	11632	Manhole	Rags/Wipes	10/14/2022	13:04	10/15/2022	14:00	8	Cleared Main Line;Cleaned and Disinfected
49662	WQ0010495002	3140 WEBSTER ST	Storm Sewer (not contained)	Yes	4710	Manhole	Collection system structural failure	10/18/2022	8:02	10/19/2022	10:13	3	Cleared Main Line;Cleaned and Disinfected
49666	WQ0010495002	5502 TELEPHONE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	10/18/2022	13:38	10/18/2022	13:39	0	Cleared Service Lateral;Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
49670	WQ0010495090	743 SHOTWELL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	10/18/2022	17:29	10/19/2022	10:08	0	Cleaned and Disinfected;Cleared Main Line
49674	WQ0010495090	737 W 21ST ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Rags/Wipes	10/19/2022	10:10	10/19/2022	10:11	0	Cleaned and Disinfected;Cleared Main Line
49675	WQ0010495090	7801 BALTIMORE ST	Storm Sewer (not contained)	Yes	414	Service Lateral	Collection system structural blockage	10/19/2022	9:24	10/19/2022	16:18	1	Cleaned and Disinfected;Set Bypass Pump
49677	WQ0010495037	3002 DOLORES PARK LN	Storm Sewer - contained	Yes	248	City Cleanout	Collection system structural blockage	10/19/2022	11:12	10/19/2022	15:19	1	Cleared Service Lateral;Cleaned and Disinfected
49679	WQ0010495016	8150 SNOWDEN ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Collection system temporary blockage	10/19/2022	11:52	10/19/2022	11:53	0	Cleared City Clean Out;Cleaned and Disinfected;
49684	WQ0010495090	6532 CANAL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	10/19/2022	15:22	10/19/2022	15:23	0	Cleaned and Disinfected;Cleared Service Lateral
49685	WQ0010495010	221 BOLDEN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	10/19/2022	16:24	10/19/2022	16:25	0	Cleared Service Lateral;Cleaned and Disinfected
49687	WQ0010495150	6227 STANDING OAKS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	10/19/2022	17:25	10/19/2022	17:26	0	Cleared Service Lateral;Cleaned and Disinfected
49689	WQ0010495090	7745 LONG POINT RD	Bayou/surface water/drainage ditch	Yes	0	Manhole	Grease Blockage	10/20/2022	12:22	10/20/2022	12:23	0	Cleared Main Line;Cleaned and Disinfected
49693	WQ0010495003	14430 MINETTA ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Grease Blockage	10/20/2022	14:56	10/20/2022	14:57	0	Cleared City Clean Out;Cleaned and Disinfected
49695	WQ0010495002	9954 STELLA LINK RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	10/20/2022	16:06	10/20/2022	16:07	0	Cleaned and Disinfected



City of Houston - Houston Public Works
Monthly SSO Report
October 2022

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
49696	WQ0010495090	1514 WIRT RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	150	Private Cleanout	Collection system temporary blockage	10/20/2022	17:20	10/20/2022	18:10	3	Cleared Service Lateral;Cleaned and Disinfected
49699	WQ0010495109	2305 HAYES RD	Storm Sewer - contained	Yes	0	Manhole	Grease Blockage	10/20/2022	18:30	10/20/2022	19:20	0	Cleared Main Line;Cleaned and Disinfected
49707	WQ0010495076	5827 VILLAGE FOREST CT	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	10/21/2022	13:40	10/21/2022	13:41	0	Cleaned and Disinfected;Cleared Main Line
49709	WQ0010495090	777 W 23RD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Rags/Wipes	10/21/2022	14:06	10/21/2022	14:07	0	Cleaned and Disinfected;Cleared Main Line
49710	WQ0010495003	2403 BRANARD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	10/21/2022	14:45	10/21/2022	14:46	0	Cleaned and Disinfected;Cleared City Clean Out
49714	WQ0010495002	1320 SCOTT ST	Storm Sewer (not contained)	Yes	2270	Manhole	Collection system structural blockage	10/21/2022	17:50	10/22/2022	12:45	2	Cleaned and Disinfected;Cleared Main Line
49718	WQ0010495111	6438 WILCREST DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	10/22/2022	9:48	10/22/2022	9:49	0	Set Bypass Pump;Cleaned and Disinfected
49721	WQ0010495003	2931 MEIKO DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	202	Private Cleanout	Grease Blockage	10/22/2022	13:14	10/22/2022	14:55	2	Cleaned and Disinfected;Cleared Service Lateral
49728	WQ0010495077	13342 JOLIET ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Grease Blockage	10/24/2022	8:30	10/24/2022	8:31	0	Cleaned and Disinfected;Cleared Main Line
49731	WQ0010495090	4420 TRAVIS ST	Storm Sewer (not contained)	Yes	1431	Manhole	Rags/Wipes	10/23/2022	13:24	10/24/2022	13:15	1	Cleaned and Disinfected;Cleared Main Line
49732	WQ0010495076	9747 CASA LOMA DR	Storm Sewer (not contained)	Yes	0	City Cleanout	Grease Blockage	10/23/2022	15:29	10/23/2022	15:30	0	Cleaned and Disinfected;Cleared Main Line

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
49733	WQ0010495090	901 W 23RD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	10/24/2022	8:52	10/24/2022	8:53	0	Set Bypass Pump;Cleaned and Disinfected;Cleared Main Line
49736	WQ0010495077	514 MAPLE WAY	Storm Sewer (not contained)	Yes	0	Service Lateral	Collection system structural blockage	10/24/2022	12:30	10/24/2022	13:30	0	Cleared Service Lateral;Cleaned and Disinfected
49740	WQ0010495002	8447 PARK PLACE BLVD	Storm Sewer (not contained)	Yes	59	City Cleanout	Grease Blockage	10/24/2022	13:11	10/24/2022	14:10	1	Cleaned and Disinfected;Cleared Service Lateral
49753	WQ0010495090	7132 AVENUE Q	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	10/26/2022	11:00	10/26/2022	11:01	0	Cleaned and Disinfected;Cleared City Clean Out
49758	WQ0010495090	9310 LONG POINT RD	Bayou/surface water/drainage ditch	Yes	165	Manhole	Grease Blockage	10/26/2022	13:39	10/26/2022	16:25	1	Cleared Main Line;Cleaned and Disinfected
49762	WQ0010495016	8037 OAK KNOLL LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	10/27/2022	14:00	10/27/2022	14:01	0	Cleaned and Disinfected;Cleared City Clean Out
49763	WQ0010495110	8227 SUMMER QUAIL DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	10/27/2022	11:14	10/27/2022	11:15	0	Cleaned and Disinfected;Cleared Main Line
49771	WQ0010495077	777 COOLWOOD DR	Storm Sewer (not contained)	Yes	160	Manhole	Grease Blockage	10/28/2022	14:30	10/28/2022	15:50	2	Cleared Main Line;Cleaned and Disinfected
49775	WQ0010495090	10145 FRIENDLY RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	10/28/2022	10:33	10/28/2022	10:34	0	Set Bypass Pump;Cleaned and Disinfected
49778	WQ0010495090	9310 LONG POINT RD	Bayou/surface water/drainage ditch	Yes	204	Manhole	Grease Blockage	10/28/2022	15:20	10/28/2022	18:45	1	Cleared Main Line;Cleaned and Disinfected
49780	WQ0010495003	3471 LOCKE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	10/28/2022	17:04	10/28/2022	17:05	0	Cleared Main Line;Cleaned and Disinfected
49786	WQ0010495003	3712 S SHEPHERD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Sample Well	Grease Blockage	10/30/2022	8:19	10/30/2022	8:20	0	Cleaned and Disinfected;Cleared Main Line


Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
October 2022

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
49790	WQ0010495037	6018 HIGH STAR DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	10/31/2022	8:22	10/31/2022	8:23	0	Cleaned and Disinfected;Cleared Main Line
49792	WQ0010495119	11150 BEECHNUT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	10	City Cleanout	Grease Blockage	10/31/2022	13:15	10/31/2022	13:55	0	Cleaned and Disinfected;Cleared Main Line
49794	WQ0010495037	10201 MAIN ST	Storm Sewer (not contained)	Yes	496	Manhole	Grease Blockage	10/31/2022	10:35	10/31/2022	14:43	2	Cleared Main Line;Cleaned and Disinfected
49799	WQ0010495002	8447 PARK PLACE BLVD	Storm Sewer (not contained)	Yes	506	City Cleanout	Rags/Wipes	10/31/2022	12:47	10/31/2022	17:00	2	Cleaned and Disinfected;Cleared Service Lateral
49806	WQ0010495090	2900 TRAVIS ST	Bayou/surface water/drainage ditch	Yes	0	Manhole	Grease Blockage	10/31/2022	15:27	10/31/2022	15:28	0	Cleaned and Disinfected;Cleared Main Line

Total Number of SSOs:	90
Number of Fish Kills Caused by SSOs:	0
Number of Notifications to the Public:	0
TWC § 7.251 Report Attached:	No



Legend

- SSO Location
- XXXXX SSO ID

Public SSO Map for October 2022



Geospatial or map data maintained by Houston Public Works is for informational purposes and may not have been prepared for or be suitable for legal, engineering, or surveying purposes. It does not represent an on-the-ground survey and only represents the approximate location of property boundaries.

Esri, HERE, Garmin, USGS, NGA, EPA, USDA, NPS