



October 17, 2024

Associate Director, Water Enforcement
U.S. Environmental Protection Agency
Region VI
1201 Elm Street, Suite 500
Mail Code ECADW
Dallas, Texas 75270-2102

Via E-mail: Smalley.bryant@epa.gov

Re: City of Houston Wastewater Consent Decree
Civil Action No. 4:18-cv-03368
Monthly SSO Report – September 2024

Dear Mr. Smalley:

The City of Houston's monthly SSO summary report for September 2024 and corresponding SSO map are attached and provided in compliance with the requirements of Paragraph 61 of the City of Houston Wastewater Consent Decree.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,
DocuSigned by:


09B3519C2697428...
Phillip Goodwin

Regulatory Compliance Director
Houston Public Works, City of Houston

Enc. September 2024 Monthly SSO Report; SSO Map for September 2024
cc via email: Thomas Carroll, DOJ (Thomas.Carroll@usdoj.gov)
James Zimny, EPA (Zimny.james@epa.gov)
Alan Vaughn, EPA (vaughn.alan@epa.gov)
Phillip Ledbetter, Texas AG's Office (phillip.ledbetter@oag.texas.gov);
James Sallans, TCEQ (james.sallans@tceq.texas.gov)
Kristen Schlemmer, BCWK (kristen@bayoucitywaterkeeper.org)

PO Box 1562 | Houston, Texas 77251-1562 | HoustonPublicWorks.org

Capital Projects | Customer Account Services | Houston Permitting Center | Houston Water | Transportation & Drainage Operations



City of Houston - Houston Public Works
Monthly SSO Report
September 2024

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
60183	WQ0010495111	11714 MOONMIST DR	Storm Sewer (not contained)	Yes	0	Manhole	Collection system temporary blockage	9/1/2024	8:30	9/1/2024	8:31	0	Set Bypass Pump; Cleaned and Disinfected; Cleared Main Line
60189	WQ0010495002	603 OGILVIE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Grease Blockage	9/2/2024	12:03	9/2/2024	12:04	0	Cleaned and Disinfected; Cleared Main Line
60192	WQ0010495002	7720 KINGSLEY ST	Bayou/surface water/drainage ditch	Yes	550	City Cleanout	Rags/Wipes	9/3/2024	8:26	9/3/2024	10:16	5	Cleaned and Disinfected; Cleared City Clean Out
60193	WQ0010495002	607 OGILVIE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/3/2024	8:16	9/3/2024	8:17	0	Cleaned and Disinfected; Cleared Main Line
60195	WQ0010495090	1655 WOODVINE DR	Storm Sewer (not contained)	Yes	235	Manhole	Rags/Wipes	9/3/2024	10:11	9/3/2024	14:06	1	Cleared Main Line; Cleaned and Disinfected
60198	WQ0010495090	2509 NAVIGATION BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	9/3/2024	9:58	9/3/2024	9:59	0	Cleared City Clean Out; Cleaned and Disinfected
60200	WQ0010495002	9631 AVENUE J	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/3/2024	14:04	9/3/2024	14:05	0	Cleaned and Disinfected; Cleared City Clean Out
60202	WQ0010495119	7926 PELLA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/3/2024	16:03	9/3/2024	16:04	0	Cleared Main Line; Cleaned and Disinfected
60203	WQ0010495037	9002 WILLOW MEADOW DR	Storm Sewer (not contained)	Yes	0	Manhole	Collection system temporary blockage	9/3/2024	16:46	9/3/2024	16:47	0	Cleared Main Line; Cleaned and Disinfected
60212	WQ0010495090	7936 FILLMORE ST	Bayou/surface water/drainage ditch	Yes	1318	City Cleanout	Grease Blockage	9/4/2024	15:41	9/5/2024	13:39	1	Cleaned and Disinfected; Cleared City Clean Out
60216	WQ0010495079	10014 KIRKGLLEN DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	150	Manhole	Grease Blockage	9/5/2024	10:31	9/5/2024	15:31	0	Cleaned and Disinfected; Cleared Main Line
60217	WQ0010495002	5501 TELEPHONE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/5/2024	9:57	9/5/2024	9:58	0	Cleaned and Disinfected
60221	WQ0010495110	15714 GATEBRIAR DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/6/2024	11:45	9/6/2024	11:46	0	Cleaned and Disinfected; Cleared City Clean Out
60223	WQ0010495090	2412 RUSSELL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	9/5/2024	14:55	9/5/2024	14:56	0	Cleaned and Disinfected
60228	WQ0010495090	5711 YALE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	68	Private Cleanout	Collection system structural failure	9/5/2024	13:27	9/5/2024	14:35	1	Cleared Service Lateral; Cleaned and Disinfected
60229	WQ0010495119	8002 GESSNER RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/6/2024	7:45	9/6/2024	7:46	0	Cleared City Clean Out; Cleaned and Disinfected
60232	WQ0010495016	9125 CADD0 RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/6/2024	9:33	9/6/2024	9:34	0	Cleaned and Disinfected
60235	WQ0010495037	7101 RENWICK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/6/2024	10:07	9/6/2024	10:08	0	Cleaned and Disinfected; Cleared City Clean Out
60239	WQ0010495109	1001 DAIRY ASHFORD RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Force Main	Air Relief Valve (ARV) Failure	9/6/2024	12:31	9/6/2024	12:32	0	Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
September 2024

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
60245	WQ0010495111	11714 MOONMIST DR	Storm Sewer (not contained)	Yes	1581	Manhole	Collection system structural blockage	9/8/2024	8:48	9/8/2024	17:35	3	Set Bypass Pump; Cleaned and Disinfected
60246	WQ0010495002	1557 GODWIN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/8/2024	8:48	9/8/2024	8:49	0	Cleared Main Line; Cleaned and Disinfected
60249	WQ0010495075	10819 SAGEGULF LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/9/2024	8:50	9/9/2024	8:51	0	Cleaned and Disinfected; Cleared Service Lateral
60253	WQ0010495119	10101 HARWIN DR	Storm Sewer (not contained)	Yes	454	Manhole	Grease Blockage	9/9/2024	11:22	9/9/2024	13:38	3	Cleared Main Line; Cleaned and Disinfected
60255	WQ0010495090	116 DORCHESTER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/9/2024	12:18	9/9/2024	12:19	0	Cleaned and Disinfected; Cleared Service Lateral
60257	WQ0010495090	3706 WICKERSHAM LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/9/2024	12:05	9/9/2024	12:06	0	Cleaned and Disinfected
60259	WQ0010495110	7629 GOUDIN DR	Storm Sewer (not contained)	Yes	231	Manhole	Grease Blockage	9/9/2024	14:44	9/9/2024	18:35	1	Cleaned and Disinfected; Cleared Main Line
60261	WQ0010495002	4734 WOODSIDE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1085	City Cleanout	Rags/Wipes	9/9/2024	15:50	9/10/2024	9:55	1	Cleared Main Line; Cleaned and Disinfected
60262	WQ0010495002	7415 MOLINE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	9/9/2024	16:28	9/9/2024	16:29	0	Cleared Main Line; Cleaned and Disinfected
60263	WQ0010495090	5612 MAY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	9/9/2024	17:00	9/9/2024	17:01	0	Cleared Main Line; Cleaned and Disinfected
60264	WQ0010495090	2408 HARDY ST	Storm Sewer (not contained)	Yes	230	City Cleanout	Grease Blockage	9/10/2024	9:06	9/10/2024	12:56	1	Cleaned and Disinfected; Cleared City Clean Out
60266	WQ0010495016	9302 KENTSHIRE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/10/2024	9:44	9/10/2024	9:45	0	Cleared City Clean Out; Cleaned and Disinfected
60270	WQ0010495112	27915 HUFFMAN CLEVELAND RD	Storm Sewer (not contained)	Yes	3000	Force Main	Collection system structural failure	9/10/2024	11:07	9/10/2024	13:00	27	Cleaned and Disinfected; Contain All or Portion of Spill
60271	WQ0010495037	6720 DE MOSS DR	Storm Sewer (not contained)	Yes	163	Manhole	Grease Blockage	9/10/2024	14:00	9/10/2024	16:43	1	Cleared Main Line; Cleaned and Disinfected
60274	WQ0010495090	720 BENNINGTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/11/2024	10:20	9/11/2024	10:21	0	Cleared City Clean Out; Cleaned and Disinfected
60275	WQ0010495109	702 PLAINWOOD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	9/11/2024	17:14	9/11/2024	17:15	0	Cleared Main Line; Cleaned and Disinfected
60276	WQ0010495016	7902 LINDA VISTA RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/12/2024	11:15	9/12/2024	11:16	0	Cleared City Clean Out; Cleaned and Disinfected
60279	WQ0010495110	16306 LAZY RIDGE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/12/2024	13:56	9/12/2024	13:57	0	Cleaned and Disinfected; Cleared Service Lateral
60284	WQ0010495090	362 RED RIPPLE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	9/13/2024	9:30	9/13/2024	9:31	0	Cleared Service Lateral; Cleaned and Disinfected
60285	WQ0010495090	2509 NAVIGATION BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	9/13/2024	9:56	9/13/2024	9:57	0	Cleaned and Disinfected



City of Houston - Houston Public Works
Monthly SSO Report
September 2024

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
60289	WQ0010495119	7230 PELLA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	9/13/2024	12:10	9/13/2024	12:11	0	Cleaned and Disinfected; Cleared Main Line
60291	WQ0010495009	9123 SCOTT ST	Storm Sewer (not contained)	Yes	0	City Cleanout	Collection system structural failure	9/14/2024	10:54	9/14/2024	10:55	0	Cleaned and Disinfected
60294	WQ0010495090	97 TIDWELL RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/14/2024	15:31	9/14/2024	15:32	0	Cleaned and Disinfected
60295	WQ0010495090	6421 BRADY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	9/15/2024	9:30	9/15/2024	9:31	0	Cleared Service Lateral; Cleaned and Disinfected
60304	WQ0010495076	3107 HOLLISTER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	9/15/2024	14:32	9/15/2024	14:33	0	Cleaned and Disinfected
60305	WQ0010495016	8422 RINN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural failure	9/15/2024	15:11	9/15/2024	15:12	0	Cleaned and Disinfected; Cleared Main Line
60306	NON-COH (14418-001)	14746 BRANCHWEST DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	248	Manhole	Grease Blockage	9/16/2024	8:13	9/16/2024	12:21	1	Cleaned and Disinfected; Cleared Main Line
60311	WQ0010495016	9827 LUM LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/16/2024	9:16	9/16/2024	9:17	0	Cleared Service Lateral; Cleaned and Disinfected
60312	WQ0010495037	8900 CHIMNEY ROCK RD	Storm Sewer (not contained)	Yes	762	Manhole	Rags/Wipes	9/16/2024	9:40	9/16/2024	13:54	3	Cleared Main Line; Cleaned and Disinfected
60316	WQ0010495003	13303 AMBROSE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/16/2024	12:45	9/16/2024	12:46	0	Cleaned and Disinfected; Cleared City Clean Out
60317	WQ0010495002	3641 MACGREGOR WAY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	212	Manhole	Rags/Wipes	9/16/2024	13:05	9/16/2024	14:51	2	Cleared Main Line; Cleaned and Disinfected
60322	WQ0010495090	1510 DOROTHY ST	Bayou/surface water/drainage ditch	Yes	448	Manhole	Grease Blockage	9/17/2024	10:16	9/17/2024	17:44	1	Cleared Main Line; Cleaned and Disinfected
60324	WQ0010495003	2503 MCCLENDON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Building Backup	Grease Blockage	9/17/2024	12:15	9/17/2024	12:16	0	Cleared Main Line; Cleaned and Disinfected
60328	WQ0010495090	9727 SWEETWATER LN	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Rags/Wipes	9/17/2024	16:20	9/17/2024	16:21	0	Cleaned and Disinfected; Cleared City Clean Out
60332	WQ0010495090	238 MEADOW LEA DR	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Collection system structural failure	9/18/2024	11:06	9/18/2024	11:07	0	Cleaned and Disinfected
60333	WQ0010495109	1714 WOODLAND PARK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	19.25	City Cleanout	Rags/Wipes	9/18/2024	13:13	9/18/2024	14:30	0	Cleared City Clean Out; Cleaned and Disinfected
60335	WQ0010495090	2313 GREGG ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	9/18/2024	15:37	9/18/2024	15:38	0	Cleaned and Disinfected; Set Bypass Pump
60342	WQ0010495037	9002 WILLOW MEADOW DR	Storm Sewer (not contained)	Yes	130	Manhole	Grease Blockage	9/20/2024	10:30	9/20/2024	12:40	1	Cleared Main Line; Cleaned and Disinfected
60343	WQ0010495010	137 ZACHARY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	143	Service Lateral	Collection system structural failure	9/20/2024	9:08	9/20/2024	11:31	1	Cleaned and Disinfected; Set Bypass Pump
60345	WQ0010495002	7170 BRACE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/20/2024	10:20	9/20/2024	10:21	0	Cleaned and Disinfected



City of Houston - Houston Public Works
Monthly SSO Report
September 2024

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
60347	WQ0010495119	7127 LONGVINE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2343	Private Cleanout	Collection system structural failure	9/20/2024	11:05	9/21/2024	13:07	2	Cleaned and Disinfected; Set Bypass Pump
60350	WQ0010495023	8326 EASTOVER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1125	Private Cleanout	Collection system structural failure	9/20/2024	15:04	9/21/2024	9:49	1	Cleared Main Line; Cleaned and Disinfected
60352	WQ0010495090	10403 BANTUM ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	9/21/2024	7:54	9/21/2024	7:55	0	Cleaned and Disinfected
60360	WQ0010495002	7111 KELLER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Grease Blockage	9/22/2024	11:30	9/22/2024	11:31	0	Cleared Main Line; Cleaned and Disinfected
60363	WQ0010495090	2056 ANTOINE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	510	Manhole	Grease Blockage	9/23/2024	10:50	9/23/2024	13:40	3	Cleared Main Line; Cleaned and Disinfected
60366	WQ0010495090	121 REBECCA ST	Storm Sewer (not contained)	Yes	0	Service Lateral	Collection system structural failure	9/23/2024	12:23	9/23/2024	12:24	0	Cleaned and Disinfected
60369	WQ0010495090	4500 MAIN ST	Storm Sewer (not contained)	Yes	200	Private Cleanout	Rags/Wipes	9/23/2024	15:40	9/23/2024	19:00	1	Cleared Service Lateral; Cleaned and Disinfected
60370	WQ0010495090	2104 43RD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/24/2024	10:46	9/24/2024	10:47	0	Cleared Main Line; Cleaned and Disinfected
60371	WQ0010495009	4222 BELLFORT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	9/24/2024	12:05	9/24/2024	12:06	0	Cleaned and Disinfected; Set Bypass Pump; Cleared Service Lateral
60374	WQ0010495090	929 25TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/24/2024	14:30	9/24/2024	14:31	0	Cleaned and Disinfected
60377	WQ0010495023	7927 BONAIRE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/24/2024	16:32	9/24/2024	16:33	0	Cleaned and Disinfected
60381	WQ0010495037	8400 HEARTH DR	Storm Sewer (not contained)	Yes	2200	Force Main	Collection system structural failure	9/25/2024	8:29	9/26/2024	9:00	1	Cleaned and Disinfected; Contain All or Portion of Spill
60384	WQ0010495050	1127 LASKEY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/25/2024	11:00	9/25/2024	11:01	0	Cleared Main Line; Cleaned and Disinfected
60385	WQ0010495002	1719 LOMBARDY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/25/2024	13:23	9/25/2024	13:24	0	Cleaned and Disinfected; Cleared City Clean Out
60386	WQ0010495003	1850 COLQUITT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/26/2024	9:45	9/26/2024	9:46	0	Cleaned and Disinfected; Cleared City Clean Out
60388	WQ0010495090	1302 LOOP FWY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/26/2024	9:45	9/26/2024	9:46	0	Cleaned and Disinfected
60389	WQ0010495090	9223 LONG POINT RD	Bayou/surface water/drainage ditch	Yes	0	Private Cleanout	Collection system structural failure	9/26/2024	9:49	9/26/2024	9:50	0	Set Bypass Pump; Cleaned and Disinfected
60392	WQ0010495002	8320 FOUNTAIN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/26/2024	10:43	9/26/2024	10:44	0	Cleared City Clean Out; Cleaned and Disinfected



City of Houston - Houston Public Works
Monthly SSO Report
September 2024

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
60395	WQ0010495002	3615 OLD SPANISH TRL	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/26/2024	12:54	9/26/2024	12:55	0	Cleared City Clean Out; Cleaned and Disinfected
60402	WQ0010495023	6922 JAY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/27/2024	12:37	9/27/2024	12:38	0	Cleared Service Lateral; Cleaned and Disinfected
60403	WQ0010495002	5922 HONEYSUCKLE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/27/2024	13:41	9/27/2024	13:42	0	Cleared City Clean Out; Cleaned and Disinfected
60404	WQ0010495002	4734 WOODSIDE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/27/2024	15:23	9/27/2024	15:24	0	Cleared Service Lateral; Cleaned and Disinfected
60405	WQ0010495002	5317 LEE LAND ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	9/27/2024	16:31	9/27/2024	16:32	0	Cleaned and Disinfected; Cleared Service Lateral
60409	WQ0010495002	8517 COMAL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/28/2024	8:33	9/28/2024	8:34	0	Cleaned and Disinfected; Cleared City Clean Out
60410	WQ0010495090	1908 CARR ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/28/2024	10:38	9/28/2024	10:39	0	Cleared City Clean Out; Cleaned and Disinfected
60411	WQ0010495146	3410 NORTHPARK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1326	Manhole	Grease Blockage	9/29/2024	8:43	9/29/2024	16:05	3	Cleaned and Disinfected; Cleared Main Line
60417	WQ0010495003	1701 COMMONWEALTH ST	Storm Sewer - contained on site	No	0	City Cleanout	Rags/Wipes	9/30/2024	8:46	9/30/2024	8:47	0	Cleared City Clean Out; Cleaned and Disinfected
60418	WQ0010495090	741 21ST ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	330	Private Cleanout	Collection system structural blockage	9/30/2024	11:45	9/30/2024	17:15	1	Set Bypass Pump; Cleaned and Disinfected
60424	WQ0010495090	240 MEADOW LEA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	9/30/2024	16:22	9/30/2024	16:23	0	Cleared Service Lateral; Cleaned and Disinfected

Total Number of SSOs:	88
Number of Fish Kills Caused:	0
Number of Notifications to TWC § 7.251 Report:	0
Attached:	No

