



May 20, 2025

Associate Director, Water Enforcement
U.S. Environmental Protection Agency
Region VI
1201 Elm Street, Suite 500
Mail Code ECADW
Dallas, Texas 75270-2102

Via E-mail: Smalley.bryant@epa.gov


Re: City of Houston Wastewater Consent Decree
Civil Action No. 4:18-cv-03368
Monthly SSO Report – April 2025

Dear Mr. Smalley:

The City of Houston's monthly SSO summary report for April 2025 and corresponding SSO map are attached and provided in compliance with the requirements of Paragraph 61 of the City of Houston Wastewater Consent Decree.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

DocuSigned by:
Phillip Goodwin

Phillip Goodwin

Senior Assistant Director
Houston Public Works, City of Houston

Enc. April 2025 Monthly SSO Report; SSO Map for April 2025
cc via email: Thomas Carroll, DOJ (Thomas.Carroll@usdoj.gov)
James Zimny, EPA (Zimny.james@epa.gov)
Alan Vaughn, EPA (vaughn.alan@epa.gov)
Brittany Wright, Texas AG's Office (Brittany.Wright@oag.texas.gov)
James Sallans, TCEQ (james.sallans@tceq.texas.gov)
Kristen Schlemmer, BCWK (kristen@bayoucitywaterkeeper.org)

PO Box 1562 | Houston, Texas 77251-1562 | HoustonPublicWorks.org

Capital Projects | Customer Account Services | Houston Permitting Center | Houston Water | Transportation & Drainage Operations



City of Houston - Houston Public Works
Monthly SSO Report
April 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63146	WQ0010495023	7820 QUEEN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/1/2025	9:01	4/1/2025	9:02	0	Cleaned and Disinfected
63152	WQ0010495090	5120 KARCHER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	4/1/2025	10:31	4/1/2025	10:32	0	Cleaned and Disinfected; Set Bypass Pump
63154	WQ0010495090	902 HARRINGTON ST	Bayou/surface water/drainage ditch	Yes	1443	City Cleanout	Collection system structural failure	4/1/2025	10:57	4/2/2025	11:00	1	Set Bypass Pump; Cleaned and Disinfected
63155	WQ0010495002	3635 BROCK ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/1/2025	12:13	4/1/2025	12:14	0	Cleaned and Disinfected
63157	WQ0010495119	9916 BROOKLET DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	4/1/2025	14:21	4/1/2025	14:22	0	Cleaned and Disinfected
63159	WQ0010495116	2100 TANGLEWILDE	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1428	Private Cleanout	Collection system structural failure	4/1/2025	15:22	4/2/2025	14:57	1	Set Bypass Pump; Cleaned and Disinfected
63160	WQ0010495090	7006 CAROTHERS ST	Bayou/surface water/drainage ditch	Yes	1193	City Cleanout	Rags/Wipes	4/1/2025	17:37	4/2/2025	13:30	1	Cleared Main Line; Cleaned and Disinfected; Cleared Service Lateral
63162	WQ0010495037	10100 GESSNER DR	Storm Sewer (not contained)	Yes	1141	Manhole	Grease Blockage	4/2/2025	7:53	4/2/2025	12:08	4	Cleared Service Lateral; Cleaned and Disinfected
63163	WQ0010495133	1303 GREENS PKWY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	4/2/2025	8:30	4/2/2025	8:31	0	Cleaned and Disinfected; Cleared Main Line
63164	WQ0010495002	2820 DALTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	4/2/2025	8:18	4/2/2025	8:19	0	Cleaned and Disinfected; Set Bypass Pump
63167	WQ0010495090	8411 IRVINGTON BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Rags/Wipes	4/2/2025	10:24	4/2/2025	10:25	0	Cleared Main Line; Cleaned and Disinfected
63179	WQ0010495090	323 72ND ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1045	Service Lateral	Grease Blockage	4/2/2025	16:35	4/3/2025	10:00	1	Cleared City Clean Out; Cleaned and Disinfected
63180	WQ0010495002	2212 POLK ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	4/3/2025	8:20	4/3/2025	8:21	0	Cleared City Clean Out; Cleaned and Disinfected
63182	WQ0010495002	8175 OGDEN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	4/3/2025	10:10	4/3/2025	10:11	0	Cleaned and Disinfected; Cleared City Clean Out
63183	WQ0010495146	3928 KINGWOOD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2000	Lift Station	Pump/Lift Station Mechanical Failure	4/1/2025	21:00	4/1/2025	23:15	15	Set Bypass Pump; Cleaned and Disinfected; Returned Spill to Sanitary System
63184	WQ0010495090	3201 LAURA KOPPE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	4/3/2025	11:23	4/3/2025	11:24	0	Cleaned and Disinfected; Cleared City Clean Out
63185	WQ0010495112	12238 FM 1960 RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2000	Force Main	Collection system structural failure	4/1/2025	14:12	4/1/2025	16:00	19	Contain All or Portion of Spill; Post Warning Signs
63190	WQ0010495002	7002 KELLER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	4/3/2025	16:39	4/3/2025	16:40	0	Cleared City Clean Out; Cleaned and Disinfected
63191	WQ0010495003	3402 LAS PALMAS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	4/4/2025	8:30	4/4/2025	8:31	0	Cleaned and Disinfected; Cleared Main Line

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
April 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63196	WQ0010495119	8735 RYLANDER CIR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	4/4/2025	11:49	4/4/2025	11:50	0	Cleaned and Disinfected
63201	WQ0010495090	6020 TRURO ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	4/4/2025	14:35	4/4/2025	14:36	0	Cleared Main Line; Cleaned and Disinfected
63202	WQ0010495003	6515 ROCKBY DR	Storm Sewer (not contained)	Yes	0	City Cleanout	Rags/Wipes	4/4/2025	16:06	4/4/2025	16:07	0	Cleared City Clean Out; Cleaned and Disinfected
63203	WQ0010495030	9235 WESTHEIMER RD	Storm Sewer (not contained)	Yes	710	Manhole	Grease Blockage	4/4/2025	16:30	4/4/2025	22:25	2	Cleared Main Line; Cleaned and Disinfected
63211	WQ0010495030	9231 WESTHEIMER RD	Storm Sewer (not contained)	Yes	3000	Manhole	Grease Blockage	4/5/2025	12:15	4/5/2025	18:30	8	Cleared Service Lateral; Cleaned and Disinfected
63215	WQ0010495037	6158 CEDAR CREEK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system temporary blockage	4/6/2025	10:36	4/6/2025	10:37	0	Cleared Service Lateral; Cleaned and Disinfected; Cleared Main Line
63221	WQ0010495111	12133 WHITE CAP LN	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	4/7/2025	9:41	4/7/2025	9:42	0	Set Bypass Pump; Cleared Main Line; Cleaned and Disinfected
63225	WQ0010495077	12806 COULSON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural failure	4/7/2025	13:51	4/7/2025	13:52	0	Cleaned and Disinfected
63227	WQ0010495076	8008 GROW LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	3732	Private Cleanout	Grease Blockage	4/7/2025	14:59	4/8/2025	11:43	3	Cleared Main Line; Cleaned and Disinfected
63231	WQ0010495002	5510 PERSHING ST	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	4/7/2025	15:58	4/7/2025	15:59	0	Cleaned and Disinfected; Cleared Main Line
63232	WQ0010495090	4102 MANGUM RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2114	City Cleanout	Grease Blockage	4/7/2025	15:53	4/8/2025	10:00	2	Cleared Service Lateral; Cleaned and Disinfected
63234	WQ0010495002	1501 ST EMANUEL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	4/7/2025	16:34	4/7/2025	16:35	0	Cleared Main Line; Cleaned and Disinfected
63235	WQ0010495002	7360 SANTA FE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	4/7/2025	16:21	4/7/2025	16:22	0	Cleaned and Disinfected; Cleared City Clean Out
63237	WQ0010495037	10600 GESSNER DR	Storm Sewer (not contained)	Yes	98	Manhole	Grease Blockage	4/7/2025	18:13	4/8/2025	12:40	0	Cleared Main Line; Cleaned and Disinfected
63238	WQ0010495002	8351 PARK PLACE BLVD	Storm Sewer (not contained)	Yes	541	City Cleanout	Collection system structural failure	4/8/2025	7:56	4/8/2025	16:57	1	Cleaned and Disinfected
63239	WQ0010495002	5525 CHENNAULT RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	4/8/2025	8:32	4/8/2025	8:33	0	Set Bypass Pump; Cleaned and Disinfected
63241	WQ0010495090	420 CAPLIN ST	Bayou/surface water/drainage ditch	Yes	0	Service Lateral	Grease Blockage	4/8/2025	8:59	4/8/2025	9:00	0	Cleared Main Line; Cleaned and Disinfected
63246	WQ0010495090	3816 SAKOWITZ ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	4/8/2025	9:12	4/8/2025	9:13	0	Cleared Main Line; Cleaned and Disinfected
63247	WQ0010495078	400 GREENS RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	52.5	Manhole	Grease Blockage	4/8/2025	9:45	4/8/2025	11:30	0	Cleaned and Disinfected; Cleared Main Line
63249	WQ0010495112	24119 GLENGYLE CT	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system - wet weather	4/5/2025	18:00	4/5/2025	18:01	0	Cleaned and Disinfected
63252	WQ0010495023	5410 EASTLAND ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	4/8/2025	11:25	4/8/2025	11:26	0	Cleared City Clean Out; Cleaned and Disinfected



City of Houston - Houston Public Works
Monthly SSO Report
April 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63255	WQ0010495090	2711 COCHRAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	4/8/2025	12:54	4/8/2025	12:55	0	Cleared Main Line; Cleaned and Disinfected
63267	WQ0010495030	790 BATESWOOD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	4/9/2025	10:17	4/9/2025	10:18	0	Cleared Main Line; Cleaned and Disinfected
63269	WQ0010495119	8517 BEECHNUT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	4/9/2025	10:11	4/9/2025	10:12	0	Cleared City Clean Out; Cleaned and Disinfected
63270	WQ0010495016	7727 TRAVIS PARK LN	Storm Sewer (not contained)	Yes	293	Manhole	Rags/Wipes	4/9/2025	9:32	4/9/2025	19:18	0	Cleaned and Disinfected; Cleared Main Line
63273	WQ0010495003	406 PACIFIC ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	4/9/2025	12:42	4/9/2025	12:43	0	Set Bypass Pump; Cleaned and Disinfected
63275	WQ0010495090	3915 FOX ST	Bayou/surface water/drainage ditch	Yes	260	City Cleanout	Grease Blockage	4/9/2025	12:39	4/9/2025	14:49	2	Cleaned and Disinfected; Cleared Main Line
63276	WQ0010495090	4822 EIGEL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	136	Manhole	Grease Blockage	4/9/2025	13:10	4/9/2025	15:26	1	Cleaned and Disinfected; Cleared Main Line
63277	WQ0010495016	7719 JOSHUA STONE ST	Storm Sewer (not contained)	Yes	177	Manhole	Rags/Wipes	4/9/2025	13:24	4/9/2025	19:18	0	Cleared Main Line; Cleaned and Disinfected
63278	WQ0010495077	12620 MARKET ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system temporary blockage	4/9/2025	14:54	4/10/2025	22:34	0	Cleared City Clean Out; Cleaned and Disinfected
63284	WQ0010495090	1423 TEANAWAY LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/10/2025	8:05	4/10/2025	8:06	0	Cleaned and Disinfected
63285	WQ0010495111	6799 WILCREST DR	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	4/10/2025	8:08	4/10/2025	8:09	0	Cleared Main Line; Cleaned and Disinfected
63287	WQ0010495002	3011 GOLFCREST BLVD	Bayou/surface water/drainage ditch	Yes	0	Service Lateral	Grease Blockage	4/10/2025	11:20	4/10/2025	11:21	0	Cleared Main Line; Cleaned and Disinfected
63293	WQ0010495016	8805 HOMESTEAD RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	274	Manhole	Grease Blockage	4/10/2025	15:44	4/10/2025	18:01	2	Cleared Main Line; Cleaned and Disinfected
63294	WQ0010495090	1201 FANNIN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	258	Manhole	Grease Blockage	4/10/2025	16:02	4/10/2025	20:20	1	Cleared Main Line; Cleaned and Disinfected
63301	WQ0010495010	306 NEW HAMPSHIRE ST	Bayou/surface water/drainage ditch	Yes	590	City Cleanout	Rags/Wipes	4/11/2025	10:21	4/11/2025	15:16	2	Cleared City Clean Out; Cleaned and Disinfected
63303	WQ0010495148	8603 VALLEY SONG DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	4/11/2025	11:04	4/11/2025	11:05	0	Cleared Service Lateral; Cleaned and Disinfected
63310	WQ0010495002	6742 ROXBURY RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/12/2025	9:58	4/12/2025	9:59	0	Cleaned and Disinfected
63312	WQ0010495119	10911 BELLFORT AVE	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	80	Service Lateral	Rags/Wipes	4/12/2025	16:35	4/12/2025	17:15	2	Cleared Main Line; Cleaned and Disinfected
63316	WQ0010495002	3514 PECAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/13/2025	14:36	4/13/2025	14:37	0	Cleaned and Disinfected
63317	WQ0010495002	6831 REED RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	179	Private Cleanout	Grease Blockage	4/14/2025	8:31	4/14/2025	11:30	1	Cleared City Clean Out; Cleaned and Disinfected
63318	WQ0010495076	7863 GREEN LAWN DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2586	City Cleanout	Rags/Wipes	4/14/2025	9:41	4/14/2025	18:30	5	Cleared City Clean Out; Cleaned and Disinfected



City of Houston - Houston Public Works
Monthly SSO Report
April 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63319	WQ0010495090	6519 MAYBANK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	90	Manhole	Grease Blockage	4/14/2025	9:03	4/14/2025	13:30	0	Cleared Main Line; Cleaned and Disinfected
63320	WQ0010495119	9916 BROOKLET DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	279	Private Cleanout	Collection system structural failure	4/14/2025	9:53	4/14/2025	14:32	1	Cleared Service Lateral; Cleaned and Disinfected
63321	WQ0010495002	6008 DEL RIO ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	4/14/2025	10:26	4/14/2025	10:27	0	Cleaned and Disinfected; Cleared Main Line
63323	WQ0010495090	2115 MCKEE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	4/14/2025	11:55	4/14/2025	11:56	0	Cleared City Clean Out; Cleaned and Disinfected
63324	WQ0010495002	4520 HOLMES RD	Storm Sewer (not contained)	Yes	301	Manhole	Grease Blockage	4/14/2025	12:08	4/14/2025	17:09	1	Cleaned and Disinfected; Cleared Main Line
63325	WQ0010495090	2117 MCKEE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	183	City Cleanout	Collection system structural blockage	4/14/2025	12:46	4/14/2025	15:49	1	Cleared City Clean Out; Cleaned and Disinfected
63326	WQ0010495077	12620 MARKET ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	4/14/2025	13:22	4/14/2025	13:23	0	Cleared Main Line; Cleaned and Disinfected
63327	WQ0010495009	5102 HOWCHER ST	Within 5 ft. of Bayou/Surface Water/Drainage Ditch	Yes	0	City Cleanout	Rags/Wipes	4/14/2025	14:34	4/14/2025	14:35	0	Cleaned and Disinfected; Cleared City Clean Out
63328	WQ0010495002	8351 PARK PLACE BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2254	City Cleanout	Rags/Wipes	4/14/2025	17:40	4/15/2025	12:27	2	Cleared City Clean Out; Cleaned and Disinfected
63333	WQ0010495090	1819 POST OAK PARK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	28	Manhole	Collection system structural failure	4/14/2025	10:27	4/14/2025	10:55	1	Cleaned and Disinfected; Set Bypass Pump
63336	WQ0010495002	6834 WESTOVER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/15/2025	11:15	4/15/2025	11:16	0	Set Bypass Pump; Cleaned and Disinfected
63337	WQ0010495002	2323 PROSPECT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/15/2025	12:20	4/15/2025	12:21	0	Cleaned and Disinfected
63340	WQ0010495119	10816 BELLFORT AVE	Storm Sewer (not contained)	Yes	462	Private Cleanout	Grease Blockage	4/15/2025	14:41	4/15/2025	18:32	2	Cleaned and Disinfected; Cleared Main Line
63347	WQ0010495002	2217 ARBOR ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	4/16/2025	11:26	4/16/2025	11:27	0	Cleaned and Disinfected; Set Bypass Pump
63349	WQ0010495090	4102 MANGUM RD	Storm Sewer (not contained)	Yes	283	Manhole	Grease Blockage	4/16/2025	11:47	4/16/2025	16:30	1	Cleared Service Lateral; Cleaned and Disinfected
63353	WQ0010495003	14415 HIRAM CLARKE RD	Storm Sewer (not contained)	Yes	0	City Cleanout	Rags/Wipes	4/16/2025	16:53	4/16/2025	16:54	0	Cleared City Clean Out; Cleaned and Disinfected
63361	WQ0010495090	1839 LAVERNE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	144	City Cleanout	Collection system temporary blockage	4/17/2025	12:51	4/17/2025	15:15	1	Cleaned and Disinfected
63362	WQ0010495037	9703 KIT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	4/17/2025	13:56	4/17/2025	13:57	0	Cleared City Clean Out; Cleaned and Disinfected
63363	WQ0010495109	2305 HAYES RD	Storm Sewer (not contained)	Yes	308	Manhole	Grease Blockage	4/17/2025	13:57	4/17/2025	16:31	2	Cleaned and Disinfected; Cleared Main Line
63373	WQ0010495002	1123 VERA LOU ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/19/2025	8:05	4/19/2025	8:06	0	Cleaned and Disinfected
63375	WQ0010495016	9306 SHERBOURNE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/19/2025	9:36	4/19/2025	9:37	0	Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
April 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63376	WQ0010495090	1836 POLK ST	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	4/20/2025	7:46	4/20/2025	7:47	0	Cleared Main Line; Cleaned and Disinfected
63381	WQ0010495002	4520 HOLMES RD	Storm Sewer (not contained)	Yes	64	Manhole	Collection system - wet weather	4/21/2025	9:56	4/21/2025	11:00	1	Cleared Main Line; Cleaned and Disinfected
63382	WQ0010495119	10911 BELLFORT AVE	Storm Sewer (not contained)	Yes	171	Private Sample Well	Grease Blockage	4/21/2025	9:46	4/21/2025	12:37	1	Cleaned and Disinfected; Cleared Main Line
63383	WQ0010495077	12620 MARKET ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	4/21/2025	12:52	4/21/2025	12:53	0	Cleared City Clean Out; Cleaned and Disinfected
63385	WQ0010495002	2314 SIEBER DR	Storm Sewer (not contained)	Yes	0	Manhole	Collection system temporary blockage	4/21/2025	13:00	4/21/2025	13:01	0	Cleaned and Disinfected
63386	WQ0010495003	4127 HARTSVILLE RD	Storm Sewer (not contained)	Yes	1080	Manhole	Pump/Lift Station Mechanical Failure	4/21/2025	13:54	4/21/2025	17:30	5	Cleaned and Disinfected; Post Warning Signs
63387	WQ0010495002	1735 PASADENA ST	Bayou/surface water/drainage ditch	Yes	0	Manhole	Power Outage	4/21/2025	9:00	4/21/2025	9:01	0	Cleaned and Disinfected
63388	WQ0010495050	1235 GLOBE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system - wet weather	4/21/2025	16:37	4/21/2025	16:38	0	Cleaned and Disinfected
63390	WQ0010495002	6606 KELLER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	4/21/2025	17:15	4/21/2025	17:16	0	Cleared Main Line; Cleaned and Disinfected
63391	WQ0010495002	6602 KELLER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	4/21/2025	17:26	4/21/2025	17:27	0	Cleaned and Disinfected; Cleared Main Line
63392	WQ0010495090	5405 BORDLEY DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	780	Manhole	Rags/Wipes	4/21/2025	8:15	4/21/2025	21:15	1	Cleaned and Disinfected; Cleared Main Line
63393	WQ0010495109	702 PLAINWOOD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	4/22/2025	8:16	4/22/2025	8:17	0	Cleared Main Line; Cleaned and Disinfected
63394	WQ0010495037	3727 TARTAN LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/22/2025	8:05	4/22/2025	8:06	0	Cleaned and Disinfected
63395	WQ0010495119	9670 AZEEM AVE	Storm Sewer (not contained)	Yes	4505	Private Cleanout	Grease Blockage	4/22/2025	8:29	4/23/2025	18:00	2	Cleared Main Line; Cleaned and Disinfected
63401	WQ0010495050	2323 2/3 THETA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system temporary blockage	4/22/2025	12:00	4/22/2025	12:01	0	Cleaned and Disinfected
63403	WQ0010495009	5025 PEDERSON ST	Storm Sewer (not contained)	Yes	114	Manhole	Grease Blockage	4/22/2025	14:15	4/22/2025	16:09	1	Cleared Main Line; Cleaned and Disinfected
63408	WQ0010495003	3214 BANDELL DR	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	4/22/2025	15:19	4/22/2025	15:20	0	Cleared Main Line; Cleaned and Disinfected
63414	WQ0010495090	1713 PANNELL ST	Storm Sewer - contained	No	1136	City Cleanout	Collection system structural failure	4/23/2025	15:49	4/24/2025	10:45	1	Cleaned and Disinfected
63417	WQ0010495111	7099 GREENWAY CHASE ST	Storm Sewer (not contained)	Yes	1430	Manhole	Grease Blockage	4/24/2025	9:27	4/24/2025	14:13	5	Cleared Main Line; Cleaned and Disinfected
63423	WQ0010495090	8007 CAPITOL ST	Storm Sewer (not contained)	Yes	0	Manhole	Collection system temporary blockage	4/21/2025	9:00	4/21/2025	9:01	0	Cleaned and Disinfected
63424	WQ0010495002	1735 PASADENA ST	Bayou/surface water/drainage ditch	Yes	0	Manhole	Power Outage	4/21/2025	9:00	4/21/2025	9:01	0	Cleaned and Disinfected
63425	WQ0010495090	524 TEETSHORN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/24/2025	13:29	4/24/2025	13:30	0	Cleaned and Disinfected



City of Houston - Houston Public Works
Monthly SSO Report
April 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63428	WQ0010495090	808 FORTUNE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	150	Private Cleanout	Collection system structural failure	4/24/2025	14:36	4/25/2025	14:15	0	Set Bypass Pump; Cleaned and Disinfected
63432	WQ0010495003	2625 WESTGATE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/24/2025	15:36	4/24/2025	15:37	0	Cleaned and Disinfected; Set Bypass Pump
63433	WQ0010495003	4412 MONTROSE BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/24/2025	17:11	4/24/2025	17:12	0	Set Bypass Pump; Cleaned and Disinfected
63434	WQ0010495050	503 REGAL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	4/24/2025	16:40	4/24/2025	16:41	0	Cleared Main Line; Cleaned and Disinfected
63435	WQ0010495002	6634 CRESTHILL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/25/2025	8:00	4/25/2025	8:01	0	Cleaned and Disinfected; Set Bypass Pump
63436	WQ0010495002	7665 EDNA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	4/25/2025	8:44	4/25/2025	8:45	0	Cleared City Clean Out; Cleaned and Disinfected
63437	WQ0010495002	6834 WESTOVER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/25/2025	9:26	4/25/2025	9:27	0	Cleaned and Disinfected
63439	WQ0010495002	7403 SANTA FE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	4/25/2025	11:26	4/25/2025	11:27	0	Cleaned and Disinfected
63441	WQ0010495090	1545 BLALOCK RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	4/25/2025	12:49	4/25/2025	12:50	0	Cleaned and Disinfected
63442	WQ0010495090	2933 KIRK ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	4/25/2025	14:00	4/25/2025	14:01	0	Cleaned and Disinfected; Cleared City Clean Out
63444	WQ0010495002	3001 HOLMAN ST	Within 5 ft. of Bayou/Surface Water/Drainage Ditch	Yes	0	City Cleanout	Grease Blockage	4/25/2025	15:33	4/25/2025	15:34	0	Cleared City Clean Out; Cleaned and Disinfected
63445	WQ0010495090	8515 HAMMERLY BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	4/25/2025	15:18	4/25/2025	15:19	0	Cleared Main Line; Cleaned and Disinfected
63446	WQ0010495002	7415 LAWDALE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	4320	Manhole	Rags/Wipes	4/25/2025	15:47	4/28/2025	15:47	1	Cleared Main Line; Cleaned and Disinfected
63447	WQ0010495030	10002 MEADOW LAKE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural blockage	4/25/2025	15:57	4/25/2025	15:58	0	Cleaned and Disinfected
63448	WQ0010495016	9603 HOMESTEAD RD	Storm Sewer (not contained)	Yes	140	Manhole	Grease Blockage	4/26/2025	9:47	4/26/2025	14:27	0	Cleared Main Line; Cleaned and Disinfected
63460	WQ0010495002	4139 ERBY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	4/28/2025	9:40	4/28/2025	9:41	0	Cleaned and Disinfected; Cleared Main Line
63465	WQ0010495090	1815 TERRY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Rags/Wipes	4/28/2025	13:04	4/28/2025	13:05	0	Cleaned and Disinfected; Cleared Main Line
63468	WQ0010495090	749 YORKSHIRE ST	Bayou/surface water/drainage ditch	Yes	0	Service Lateral	Collection system structural failure	4/28/2025	14:07	4/28/2025	14:08	0	Cleaned and Disinfected
63469	WQ0010495090	1111 PORTWALL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	4/28/2025	16:33	4/28/2025	16:34	0	Cleared Main Line; Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
April 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63475	WQ0010495090	7418 GAINESVILLE ST	Bayou/surface water/drainage ditch	Yes	1291	Service Lateral	Collection system structural blockage	4/29/2025	11:11	4/30/2025	8:42	1	Cleaned and Disinfected
63479	WQ0010495002	3903 ERBY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	4/29/2025	13:16	4/29/2025	13:17	0	Cleaned and Disinfected
63483	WQ0010495002	3212 MCGOWEN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	4/29/2025	16:45	4/29/2025	16:46	0	Cleaned and Disinfected
63485	WQ0010495037	7135 NEFF ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	4/30/2025	7:34	4/30/2025	7:35	0	Cleaned and Disinfected; Set Bypass Pump
63500	WQ0010495090	1825 JACQUELYN DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	4/30/2025	16:22	4/30/2025	16:23	0	Cleaned and Disinfected
63503	WQ0010495095	7825 WINDWARD PASSAGE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	4/30/2025	17:33	4/30/2025	17:34	0	Cleared City Clean Out; Cleaned and Disinfected

Total Number of SSOs:	129
Number of Fish Kills Caused by SSOs:	0
Number of Notifications to the Public:	0
TWC § 7.251 Report Attached:	No

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.

