



June 20, 2025

Associate Director, Water Enforcement  
U.S. Environmental Protection Agency  
Region VI  
1201 Elm Street, Suite 500  
Mail Code ECADW  
Dallas, Texas 75270-2102

Via E-mail: [Smalley.bryant@epa.gov](mailto:Smalley.bryant@epa.gov)

Re: City of Houston Wastewater Consent Decree  
Civil Action No. 4:18-cv-03368  
Monthly SSO Report – May 2025

Dear Mr. Smalley:

The City of Houston's monthly SSO summary report for May 2025 and corresponding SSO map are attached and provided in compliance with the requirements of Paragraph 61 of the City of Houston Wastewater Consent Decree.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,

A blue DocuSign signature line with a stylized signature in blue ink.

00B3519C2697428...  
Phillip Goodwin

Senior Assistant Director  
Houston Public Works, City of Houston

Enc. May 2025 Monthly SSO Report; SSO Map for May 2025  
cc via email: Thomas Carroll, DOJ ([Thomas.Carroll@usdoj.gov](mailto:Thomas.Carroll@usdoj.gov))  
James Zimny, EPA ([Zimny.james@epa.gov](mailto:Zimny.james@epa.gov))  
Alan Vaughn, EPA ([vaughn.alan@epa.gov](mailto:vaughn.alan@epa.gov))  
Brittany Wright, Texas AG's Office ([Brittany.Wright@oag.texas.gov](mailto:Brittany.Wright@oag.texas.gov))  
James Sallans, TCEQ ([james.sallans@tceq.texas.gov](mailto:james.sallans@tceq.texas.gov))  
Kristen Schlemmer, BCWK ([kristen@bayoucitywaterkeeper.org](mailto:kristen@bayoucitywaterkeeper.org))

PO Box 1562 | Houston, Texas 77251-1562 | [HoustonPublicWorks.org](http://HoustonPublicWorks.org)

Capital Projects | Customer Account Services | Houston Permitting Center | Houston Water | Transportation & Drainage Operations



City of Houston - Houston Public Works  
Monthly SSO Report  
May 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63504	WQ0010495090	6406 PINESHADE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	5/1/2025	11:30	5/1/2025	11:31	0	Cleaned and Disinfected
63505	WQ0010495003	2000 HOLLY HALL ST	Storm Sewer (not contained)	Yes	936	Manhole	Grease Blockage	5/1/2025	8:24	5/1/2025	10:48	6	Cleared Main Line; Cleaned and Disinfected
63513	WQ0010495090	5642 PATRICK ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system temporary blockage	5/1/2025	13:41	5/1/2025	13:42	0	Cleaned and Disinfected
63514	WQ0010495076	6440 43RD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Sample Well	Grease Blockage	5/1/2025	14:28	5/1/2025	14:29	0	Cleaned and Disinfected; Set Bypass Pump
63516	WQ0010495090	3214 OMEGA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	5/2/2025	8:41	5/2/2025	8:42	0	Cleaned and Disinfected
63517	WQ0010495090	1093 ELLINGTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	5/2/2025	8:51	5/2/2025	8:52	0	Cleared Main Line; Cleaned and Disinfected
63520	WQ0010495037	6122 FAIRDALE LN	Bayou/surface water/drainage ditch	Yes	1035	City Cleanout	Grease Blockage	5/2/2025	17:18	5/2/2025	20:45	5	Cleaned and Disinfected; Cleared Main Line
63521	WQ0010495037	9215 FORDSHIRE DR	Storm Sewer (not contained)	Yes	1380	City Cleanout	Rags/Wipes	5/2/2025	16:59	5/2/2025	21:35	5	Cleared City Clean Out; Cleaned and Disinfected
63525	WQ0010495090	7413 NAVIGATION BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/3/2025	11:00	5/3/2025	11:01	0	Cleared City Clean Out; Cleaned and Disinfected
63529	WQ0010495002	2724 BROADWAY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	5/3/2025	14:55	5/3/2025	14:56	0	Cleared Main Line; Cleaned and Disinfected
63530	WQ0010495003	1701 COMMONWEALTH ST	Storm Sewer (not contained)	Yes	0	City Cleanout	Rags/Wipes	5/4/2025	8:29	5/4/2025	8:30	0	Cleared City Clean Out; Cleaned and Disinfected
63531	WQ0010495016	7214 LAURA KOPPE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/4/2025	9:30	5/4/2025	9:31	0	Cleared City Clean Out; Cleaned and Disinfected
63535	WQ0010495146	2411 FRIARWOOD TRL	Storm Sewer (not contained)	Yes	286	Private Cleanout	Grease Blockage	5/5/2025	10:47	5/5/2025	13:10	2	Cleared Main Line; Cleaned and Disinfected
63537	WQ0010495002	6514 WESTOVER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	5/5/2025	12:18	5/5/2025	12:19	0	Cleaned and Disinfected
63538	WQ0010495077	12661 YANCY DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Grease Blockage	5/5/2025	12:58	5/5/2025	12:59	0	Cleared Main Line; Cleaned and Disinfected
63544	WQ0010495112	2720 HUFFMAN EASTGATE RD	Bayou/surface water/drainage ditch	Yes	0	Manhole	Collection system structural failure	5/3/2025	18:21	5/3/2025	18:22	0	Set Bypass Pump
63545	WQ0010495090	242 TALLANT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system temporary blockage	5/5/2025	16:01	5/5/2025	16:02	0	Cleared City Clean Out; Cleaned and Disinfected
63552	WQ0010495003	2715 ALMEDA PLAZA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	5/6/2025	8:32	5/6/2025	8:33	0	Cleared City Clean Out; Cleaned and Disinfected
63554	WQ0010495119	11555 BISSONNET ST	Storm Sewer (not contained)	Yes	1410	Manhole	Grease Blockage	5/6/2025	9:48	5/6/2025	12:09	10	Cleared Main Line; Cleaned and Disinfected
63558	WQ0010495090	2812 MORRISON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/6/2025	15:33	5/6/2025	15:34	0	Cleared City Clean Out; Cleaned and Disinfected
63562	WQ0010495037	6122 FAIRDALE LN	Storm Sewer (not contained)	Yes	195	City Cleanout	Grease Blockage	5/6/2025	16:00	5/6/2025	19:15	1	Cleared Main Line; Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works  
Monthly SSO Report  
May 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63563	WQ0010495090	2434 QUENBY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	5/6/2025	16:07	5/6/2025	16:08	0	Cleaned and Disinfected
63565	WQ0010495116	12602 ASHCLIFT DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Rags/Wipes	5/6/2025	17:46	5/6/2025	17:47	0	Cleared Main Line; Cleaned and Disinfected
63566	WQ0010495090	8515 HAMMERLY BLVD	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	5/7/2025	9:47	5/7/2025	9:48	0	Cleaned and Disinfected; Cleared Main Line
63567	WQ0010495003	3306 MERCER ST	Storm Sewer (not contained)	Yes	0	Private Cleanout	Collection system structural failure	5/7/2025	14:30	5/7/2025	14:31	0	Cleaned and Disinfected
63569	WQ0010495002	2212 POLK ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/7/2025	15:37	5/7/2025	15:38	0	Cleared City Clean Out; Cleaned and Disinfected
63575	WQ0010495002	5755 BELDART ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	5/8/2025	7:50	5/8/2025	7:51	0	Cleared Main Line; Cleaned and Disinfected
63579	WQ0010495002	712 OAKHURST ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system temporary blockage	5/8/2025	9:30	5/8/2025	9:31	0	Cleaned and Disinfected
63582	WQ0010495077	515 RAINY MEADOW LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	5/8/2025	11:00	5/8/2025	11:01	0	Cleaned and Disinfected; Cleared City Clean Out
63584	WQ0010495002	7373 ARDMORE ST	Storm Sewer (not contained)	Yes	1908.5	Service Lateral	Grease Blockage	5/8/2025	9:29	5/8/2025	17:05	4	Cleared Main Line; Cleaned and Disinfected
63585	WQ0010495016	9109 MADERA RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	5/8/2025	12:31	5/8/2025	12:32	0	Cleaned and Disinfected
63591	WQ0010495016	5430 WESTBROOK RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/8/2025	16:30	5/8/2025	16:31	0	Cleared City Clean Out; Cleaned and Disinfected
63593	WQ0010495076	6102 ROLLINS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	5/9/2025	7:59	5/9/2025	8:00	0	Cleaned and Disinfected
63596	WQ0010495079	10210 FONVILLE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	5/9/2025	9:50	5/9/2025	9:51	0	Cleaned and Disinfected; Set Bypass Pump
63597	WQ0010495149	1706 LAKESHORE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1453	Manhole	Grease Blockage	5/9/2025	10:47	5/10/2025	11:00	1	Cleaned and Disinfected; Cleared Main Line
63598	WQ0010495076	8911 MONTGOMERY RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	5/9/2025	11:11	5/9/2025	11:12	0	Cleaned and Disinfected
63602	WQ0010495002	6046 LISA LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/9/2025	15:57	5/9/2025	15:58	0	Cleaned and Disinfected; Cleared Service Lateral
63603	WQ0010495002	2323 PROSPECT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	5/9/2025	16:57	5/9/2025	16:58	0	Cleaned and Disinfected; Set Bypass Pump
63604	WQ0010495037	4754 KINGLET ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	5/9/2025	17:42	5/9/2025	17:43	0	Cleaned and Disinfected
63605	WQ0010495030	2603 FONTANA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	233	Manhole	Grease Blockage	5/10/2025	8:05	5/10/2025	11:58	1	Cleared Main Line; Cleaned and Disinfected



City of Houston - Houston Public Works  
Monthly SSO Report  
May 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63609	WQ0010495090	2930 SOLO ST	Storm Sewer (not contained)	Yes	91	Manhole	Grease Blockage	5/10/2025	11:56	5/10/2025	14:58	0	Cleared Main Line; Cleaned and Disinfected
63610	WQ0010495090	5615 LANDOR ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	5/10/2025	16:44	5/10/2025	16:45	0	Set Bypass Pump; Cleaned and Disinfected
63616	WQ0010495076	2806 VEGA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	5/11/2025	10:46	5/11/2025	10:47	0	Cleared Main Line; Cleaned and Disinfected
63617	WQ0010495003	4102 JORNS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	5/11/2025	15:11	5/11/2025	15:12	0	Cleared Main Line; Cleaned and Disinfected
63618	WQ0010495090	2619 DEAMS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	5/11/2025	15:27	5/11/2025	15:28	0	Cleared Service Lateral; Cleaned and Disinfected
63621	WQ0010495003	3660 RICHMOND AVE	Storm Sewer (not contained)	Yes	814.5	Manhole	Grease Blockage	5/12/2025	7:59	5/12/2025	11:00	4	Cleared Main Line; Cleaned and Disinfected
63623	WQ0010495076	1120 PAUL QUINN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	444	City Cleanout	Grease Blockage	5/12/2025	8:20	5/12/2025	15:44	1	Cleared Main Line; Cleaned and Disinfected
63629	WQ0010495075	11306 SAGEDOWNE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system temporary blockage	5/12/2025	13:10	5/12/2025	13:11	0	Cleaned and Disinfected
63634	WQ0010495023	8037 FILLTOP ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	5/12/2025	15:30	5/12/2025	15:31	0	Cleared City Clean Out; Cleaned and Disinfected
63635	WQ0010495076	7019 PHILLIPS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	5/12/2025	16:03	5/12/2025	16:04	0	Cleared Service Lateral
63636	WQ0010495002	8424 BROCKTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	5/12/2025	16:12	5/12/2025	16:13	0	Cleaned and Disinfected; Cleared Main Line
63647	WQ0010495090	1111 PORTWALL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	5/13/2025	10:35	5/13/2025	10:36	0	Cleaned and Disinfected; Cleared Main Line
63649	WQ0010495037	5854 SAN FELIPE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1053	Manhole	Grease Blockage	5/13/2025	11:07	5/13/2025	16:58	3	Cleared Main Line; Cleaned and Disinfected
63652	WQ0010495111	4618 BELLE PARK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system temporary blockage	5/13/2025	10:18	5/13/2025	10:19	0	Cleared Main Line; Cleaned and Disinfected
63653	WQ0010495111	12939 KNOTTY GLEN LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/13/2025	11:58	5/13/2025	11:59	0	Cleared City Clean Out; Cleaned and Disinfected
63654	WQ0010495016	8134 LAURA KOPPE RD	Within 5 ft. of Bayou/Surface Water/Drainage Ditch	Yes	0	City Cleanout	Rags/Wipes	5/13/2025	12:24	5/13/2025	12:25	0	Cleared City Clean Out; Cleaned and Disinfected
63658	WQ0010495090	1114 STUDE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	5/13/2025	14:15	5/13/2025	14:16	0	Cleared City Clean Out; Set Bypass Pump
63661	WQ0010495090	2401 MILWAUKEE ST	Storm Sewer (not contained)	Yes	0	City Cleanout	Rags/Wipes	5/13/2025	15:59	5/13/2025	16:00	0	Cleared City Clean Out; Cleaned and Disinfected
63667	WQ0010495002	7617 MAGNOLIA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	5/14/2025	8:54	5/14/2025	8:55	0	Cleaned and Disinfected; Cleared City Clean Out
63674	WQ0010495111	11602 BELLAIRE BLVD	Storm Sewer (not contained)	Yes	0	Private Sample Well	Grease Blockage	5/14/2025	20:25	5/14/2025	20:26	0	Cleaned and Disinfected; Cleared Main Line



City of Houston - Houston Public Works  
Monthly SSO Report  
May 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63678	WQ0010495090	261 SPREADING OAK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Rags/Wipes	5/15/2025	8:49	5/15/2025	8:50	0	Cleared Main Line; Cleaned and Disinfected
63681	WQ0010495037	3751 UNDERWOOD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	5/15/2025	7:11	5/15/2025	7:12	0	Cleaned and Disinfected; Cleared Main Line
63682	WQ0010495109	11315 CHEVY CHASE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	5/15/2025	13:42	5/15/2025	13:43	0	Cleaned and Disinfected
63687	WQ0010495003	3826 CHILDRESS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	280	Service Lateral	Grease Blockage	5/16/2025	8:38	5/16/2025	17:58	0	Cleared Main Line; Cleaned and Disinfected
63690	WQ0010495090	8515 HAMMERLY BLVD	Storm Sewer (not contained)	Yes	688	Manhole	Grease Blockage	5/16/2025	10:39	5/16/2025	16:23	2	Cleared Main Line; Cleaned and Disinfected
63691	WQ0010495009	13521 LAWSON WALK LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/15/2025	10:43	5/15/2025	10:44	0	Cleaned and Disinfected; Cleared City Clean Out
63694	WQ0010495090	1905 JOHANNA DR	Bayou/surface water/drainage ditch	Yes	1880	City Cleanout	Grease Blockage	5/16/2025	14:13	5/16/2025	20:29	5	Cleaned and Disinfected; Cleared Main Line
63698	WQ0010495002	6008 DEL RIO ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	5/17/2025	9:46	5/17/2025	9:47	0	Cleared Main Line; Cleaned and Disinfected; Cleared Service Lateral
63700	WQ0010495002	4828 BERRYDALE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	5/17/2025	12:07	5/17/2025	12:08	0	Set Bypass Pump; Cleaned and Disinfected
63702	WQ0010495111	12939 KNOTTY GLEN LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	5/17/2025	15:31	5/17/2025	15:32	0	Cleaned and Disinfected; Cleared City Clean Out
63708	WQ0010495119	8310 JORINE DR	Storm Sewer (not contained)	Yes	275	Manhole	Grease Blockage	5/19/2025	11:10	5/19/2025	13:00	2	Cleared Main Line; Cleaned and Disinfected
63715	WQ0010495009	6125 FUQUA ST	Bayou/surface water/drainage ditch	Yes	66	City Cleanout	Rags/Wipes	5/19/2025	12:54	5/19/2025	14:00	1	Cleaned and Disinfected; Cleared City Clean Out
63716	WQ0010495002	8355 HINMAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/19/2025	14:58	5/19/2025	14:59	0	Cleaned and Disinfected; Cleared City Clean Out
63721	WQ0010495002	328 EASTWOOD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Rags/Wipes	5/20/2025	9:56	5/20/2025	9:57	0	Cleaned and Disinfected; Cleared Main Line
63722	WQ0010495016	7826 HOMEWOOD LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	5/20/2025	11:30	5/20/2025	11:31	0	Cleared City Clean Out; Cleaned and Disinfected
63724	WQ0010495146	4930 MIDDLE FALLS DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system temporary blockage	5/20/2025	14:45	5/20/2025	14:46	0	Cleaned and Disinfected
63726	WQ0010495078	16018 ALDINE WESTFIELD RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	5/20/2025	15:20	5/20/2025	15:21	0	Cleared Main Line; Cleaned and Disinfected
63727	WQ0010495146	2615 WOODS ESTATES DR	Bayou/surface water/drainage ditch	Yes	0	Manhole	Grease Blockage	5/20/2025	10:31	5/20/2025	10:32	0	Cleared Main Line; Cleaned and Disinfected
63729	WQ0010495016	8633 CADD0 RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	5/21/2025	9:33	5/21/2025	9:34	0	Cleaned and Disinfected
63732	WQ0010495090	2407 WHITE OAK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	5/21/2025	15:32	5/21/2025	15:33	0	Cleaned and Disinfected; Cleared Main Line
63733	WQ0010495090	2440 CANAL ST	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	5/21/2025	16:04	5/21/2025	16:05	0	Cleared Main Line



City of Houston - Houston Public Works  
Monthly SSO Report  
May 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63736	WQ0010495002	3001 HOLMAN ST	Storm Sewer (not contained)	Yes	119	City Cleanout	Rags/Wipes	5/21/2025	16:45	5/21/2025	18:43	1	Cleaned and Disinfected; Cleared City Clean Out
63738	WQ0010495037	8261 RICHMOND AVE	Storm Sewer (not contained)	Yes	1070	City Cleanout	Grease Blockage	5/22/2025	7:52	5/22/2025	15:00	2	Cleared City Clean Out; Cleaned and Disinfected
63743	WQ0010495090	518 11TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	31	Private Sample Well	Grease Blockage	5/22/2025	10:55	5/22/2025	11:26	1	Cleared Main Line; Cleaned and Disinfected
63755	WQ0010495119	3774 TANGLEWILDE ST	Storm Sewer (not contained)	Yes	714	Manhole	Grease Blockage	5/23/2025	11:04	5/23/2025	15:02	3	Cleared Main Line; Cleaned and Disinfected
63756	WQ0010495009	4329 LARKSPUR ST	Bayou/surface water/drainage ditch	Yes	312	City Cleanout	Grease Blockage	5/23/2025	12:01	5/23/2025	13:45	3	Cleared City Clean Out; Cleaned and Disinfected
63759	WQ0010495090	306 NORTH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	5/23/2025	14:07	5/23/2025	14:08	0	Cleaned and Disinfected; Set Bypass Pump
63760	WQ0010495003	1104 OLD SPANISH TRL	Storm Sewer (not contained)	Yes	129	Private Cleanout	Collection system structural failure	5/23/2025	14:11	5/23/2025	16:20	1	Set Bypass Pump; Cleaned and Disinfected
63762	WQ0010495090	1309 35TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/23/2025	15:54	5/23/2025	15:55	0	Cleared Service Lateral; Cleaned and Disinfected
63763	WQ0010495009	4014 BELLFORT ST	Storm Sewer (not contained)	Yes	0	City Cleanout	Collection system structural blockage	5/23/2025	15:48	5/23/2025	15:49	0	Cleared City Clean Out; Cleaned and Disinfected
63767	WQ0010495146	4517 KINGWOOD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Pump/Lift Station Mechanical Failure	5/24/2025	16:33	5/24/2025	16:34	0	Cleaned and Disinfected; Set Bypass Pump
63773	WQ0010495002	4520 HOLMES RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Rags/Wipes	5/26/2025	9:25	5/26/2025	9:26	0	Cleaned and Disinfected; Cleared Main Line
63774	WQ0010495037	9126 KAPRI LN	Storm Sewer (not contained)	Yes	381	City Cleanout	Grease Blockage	5/26/2025	12:44	5/26/2025	14:51	3	Cleared City Clean Out; Cleaned and Disinfected
63775	WQ0010495116	12128 5TH ST	Storm Sewer (not contained)	Yes	0	Private Cleanout	Collection system structural failure	5/26/2025	13:03	5/26/2025	13:04	0	Set Bypass Pump; Cleaned and Disinfected
63777	WQ0010495003	5607 ANDERSON OAKS CT	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	5/27/2025	8:42	5/27/2025	8:43	0	Cleared Service Lateral; Cleaned and Disinfected
63782	WQ0010495002	5210 POMANDER RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	5/27/2025	12:15	5/27/2025	12:16	0	Cleaned and Disinfected; Cleared City Clean Out
63785	WQ0010495037	9126 KAPRI LN	Storm Sewer (not contained)	Yes	1326	City Cleanout	Grease Blockage	5/27/2025	16:10	5/28/2025	14:16	1	Cleared City Clean Out; Cleaned and Disinfected
63787	WQ0010495090	1349 RICHELIEU LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	5/28/2025	8:58	5/28/2025	8:59	0	Cleaned and Disinfected
63788	WQ0010495110	5007 PARKRIDGE DR	Storm Sewer (not contained)	Yes	1480	City Cleanout	Grease Blockage	5/28/2025	9:34	5/28/2025	14:30	5	Cleared Main Line; Cleaned and Disinfected
63789	WQ0010495002	4814 BELLNOLE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/28/2025	10:03	5/28/2025	10:04	0	Cleared City Clean Out; Cleaned and Disinfected
63793	WQ0010495003	2919 OREM DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	3106	Manhole	Grease Blockage	5/28/2025	16:15	5/29/2025	18:08	2	Cleared Service Lateral; Cleaned and Disinfected
63794	WQ0010495037	9955 MAIN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/29/2025	8:06	5/29/2025	8:07	0	Cleaned and Disinfected; Cleared City Clean Out



SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
63795	WQ0010495090	106 ADAMS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	5/29/2025	9:21	5/29/2025	9:22	0	Cleared Service Lateral; Cleaned and Disinfected
63796	WQ0010495003	10722 LEITRIM WAY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	5/29/2025	10:11	5/29/2025	10:12	0	Cleaned and Disinfected; Cleared City Clean Out
63811	WQ0010495090	3817 WIPPRECHT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	5/30/2025	14:00	5/30/2025	14:01	0	Cleaned and Disinfected
63815	WQ0010495111	7314 BRENDAM LN	Storm Sewer (not contained)	Yes	96	City Cleanout	Rags/Wipes	5/31/2025	10:16	5/31/2025	11:52	1	Cleared City Clean Out; Cleaned and Disinfected
63817	WQ0010495076	5668 LITTLE YORK RD	Storm Sewer (not contained)	Yes	950	Manhole	Collection system temporary blockage	5/31/2025	14:10	5/31/2025	22:05	2	Cleaned and Disinfected; Set Bypass Pump

Total Number of SSOs:	107
Number of Fish Kills Caused by SSOs:	0
Number of Notifications to the Public:	0
TWC § 7.251 Report Attached:	No

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



