



August 14, 2025

Associate Director, Water Enforcement
U.S. Environmental Protection Agency
Region VI
1201 Elm Street, Suite 500
Mail Code ECADW
Dallas, Texas 75270-2102

Via E-mail: Smalley.bryant@epa.gov


Re: City of Houston Wastewater Consent Decree
Civil Action No. 4:18-cv-03368
Monthly SSO Report – July 2025

Dear Mr. Smalley:

The City of Houston's monthly SSO summary report for July 2025 and corresponding SSO map are attached and provided in compliance with the requirements of Paragraph 61 of the City of Houston Wastewater Consent Decree.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

DocuSigned by:
Phillip Goodwin

00B3519C2697428...
Phillip Goodwin

Senior Assistant Director
Houston Public Works, City of Houston

Enc. July 2025 Monthly SSO Report; SSO Map for July 2025
cc via email: Thomas Carroll, DOJ (Thomas.Carroll@usdoj.gov)
James Zimny, EPA (Zimny.james@epa.gov)
Alan Vaughn, EPA (vaughn.alan@epa.gov)
Brittany Wright, Texas AG's Office (Brittany.Wright@oag.texas.gov)
James Sallans, TCEQ (james.sallans@tceq.texas.gov)
Kristen Schlemmer, BCWK (kristen@bayoucitywaterkeeper.org)

PO Box 1562 | Houston, Texas 77251-1562 | HoustonPublicWorks.org

Capital Projects | Customer Account Services | Houston Permitting Center | Houston Water | Transportation & Drainage Operations



City of Houston - Houston Public Works
Monthly SSO Report
July 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64126	WQ0010495079	9904 KINGSPPOINT RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural failure	7/1/2025	14:46	7/1/2025	14:47	0	Cleaned and Disinfected; Contain All or Portion of Spill
64128	WQ0010495002	2820 DALTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	7/1/2025	16:46	7/1/2025	16:47	0	Cleared City Clean Out; Cleaned and Disinfected
64131	WQ0010495090	1218 31ST ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1136	Manhole	Grease Blockage	7/2/2025	10:23	7/2/2025	15:07	4	Set Bypass Pump
64132	WQ0010495119	8231 AUGUSTINE DR	Storm Sewer (not contained)	Yes	4383	Manhole	Grease Blockage	7/2/2025	10:21	7/3/2025	10:54	3	Cleared Main Line; Cleaned and Disinfected
64134	WQ0010495076	8503 VENUS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	7/2/2025	11:10	7/2/2025	11:11	0	Contain All or Portion of Spill
64135	WQ0010495003	2511 WILLOWICK RD	Storm Sewer (not contained)	Yes	1300	Manhole	Collection system structural blockage	7/2/2025	11:08	7/2/2025	18:40	3	Cleaned and Disinfected; Set Bypass Pump
64136	WQ0010495016	7230 HALL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system temporary blockage	7/2/2025	11:57	7/2/2025	11:58	0	Cleaned and Disinfected
64139	WQ0010495037	9223 STELLA LINK RD	Storm Sewer (not contained)	Yes	460	City Cleanout	Rags/Wipes	7/2/2025	14:53	7/2/2025	16:25	5	Cleared City Clean Out; Cleaned and Disinfected
64146	WQ0010495037	3825 LOOP FWY	Storm Sewer (not contained)	Yes	315	Manhole	Grease Blockage	7/3/2025	15:30	7/3/2025	16:33	5	Cleaned and Disinfected; Cleared Main Line
64147	WQ0010495016	7427 BRETSHIRE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2676	Manhole	Grease Blockage	7/3/2025	11:30	7/4/2025	9:48	2	Cleaned and Disinfected; Cleared Main Line
64148	WQ0010495050	1110 ELTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	810	Manhole	Collection system – wet weather	7/3/2025	14:45	7/3/2025	21:30	2	Cleaned and Disinfected
64149	WQ0010495112	139 DEER LAKE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Pump/Lift Station Electrical Failure	7/3/2025	18:13	7/3/2025	18:14	0	Cleaned and Disinfected
64155	WQ0010495037	6822 STROUD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/4/2025	15:11	7/4/2025	15:12	0	Cleared Main Line; Cleaned and Disinfected
64156	WQ0010495111	11915 TROULON DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	175	City Cleanout	Grease Blockage	7/5/2025	8:22	7/5/2025	11:17	1	Cleared Main Line; Cleaned and Disinfected
64157	WQ0010495003	1206A JACKSON BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/5/2025	9:05	7/5/2025	9:06	0	Cleaned and Disinfected
64163	WQ0010495146	2910 ROYAL CIRCLE DR	Storm Sewer (not contained)	Yes	163	Manhole	Grease Blockage	7/5/2025	8:35	7/5/2025	14:00	1	Cleaned and Disinfected; Cleared Main Line
64171	WQ0010495003	2424 DUNSTAN RD	Storm Sewer (not contained)	Yes	4852	Private Cleanout	Collection system structural failure	7/6/2025	16:02	7/7/2025	12:15	4	Cleaned and Disinfected
64174	WQ0010495090	3018 LA ESTANCIA LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	7/7/2025	9:21	7/7/2025	9:22	0	Cleared Service Lateral; Cleaned and Disinfected
64175	WQ0010495090	214 MARSDEN ST	Bayou/surface water/drainage ditch	Yes	0	Service Lateral	Collection system structural failure	7/7/2025	9:25	7/7/2025	9:26	0	Cleaned and Disinfected
64176	WQ0010495003	5779 FUQUA ST	Storm Sewer (not contained)	Yes	72.5	Manhole	Grease Blockage	7/7/2025	9:26	7/7/2025	11:51	0	Cleared Main Line; Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
July 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64177	WQ0010495110	15738 RIDGEGATE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	7/7/2025	10:39	7/7/2025	10:40	0	Cleared Main Line; Cleaned and Disinfected
64181	WQ0010495003	4003 HEATHERBLOOM DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	7/7/2025	12:38	7/7/2025	12:39	0	Cleared City Clean Out; Cleaned and Disinfected
64182	WQ0010495111	10914 HAZEN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	312	City Cleanout	Rags/Wipes	7/7/2025	13:01	7/7/2025	15:37	2	Cleaned and Disinfected; Cleared City Clean Out
64187	WQ0010495090	814 ENTERPRISE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/7/2025	16:30	7/7/2025	16:31	0	Cleared Main Line; Cleaned and Disinfected
64189	WQ0010495090	6510 DE PRIEST ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	7/7/2025	17:00	7/7/2025	17:01	0	Cleaned and Disinfected
64190	WQ0010495111	10575 WESTPARK DR	Storm Sewer (not contained)	Yes	1240	Manhole	Grease Blockage	7/7/2025	16:17	7/7/2025	20:25	5	Cleared Main Line; Cleaned and Disinfected
64192	WQ0010495002	7407 MOLINE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system structural failure	7/8/2025	10:34	7/8/2025	10:35	0	Set Bypass Pump
64193	WQ0010495090	7630 AMELIA RD	Bayou/surface water/drainage ditch	Yes	150	Manhole	Grease Blockage	7/8/2025	10:54	7/9/2025	14:30	0	Cleared Main Line; Cleaned and Disinfected
64195	WQ0010495090	2011 MCKINNEY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	7/8/2025	11:42	7/8/2025	11:43	0	Cleared City Clean Out; Cleaned and Disinfected
64196	WQ0010495030	9235 WESTHEIMER RD	Storm Sewer (not contained)	Yes	644	Manhole	Grease Blockage	7/8/2025	11:49	7/8/2025	14:30	4	Cleared Main Line; Cleaned and Disinfected
64197	WQ0010495003	13314 CHISWICK RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	7/8/2025	15:58	7/8/2025	15:59	0	Cleared Service Lateral; Cleaned and Disinfected
64198	WQ0010495030	9503 MOORBERRY LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Force Main	Air Relief Valve (ARV) Failure	7/9/2025	8:30	7/9/2025	8:31	0	Cleaned and Disinfected
64199	WQ0010495037	3754 TARTAN LN	Storm Sewer (not contained)	Yes	310	Manhole	Collection system structural failure	7/9/2025	8:55	7/9/2025	11:30	2	Cleaned and Disinfected; Set Bypass Pump
64201	WQ0010495002	3927 COSBY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/9/2025	10:00	7/9/2025	10:01	0	Cleared Service Lateral; Cleaned and Disinfected
64213	WQ0010495090	9716 EDGEWORTH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	7/10/2025	9:15	7/10/2025	9:16	0	Set Bypass Pump; Cleaned and Disinfected
64219	WQ0010495037	4930 POST OAK TIMBER DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/10/2025	11:26	7/10/2025	11:27	0	Cleared Main Line; Cleaned and Disinfected
64220	WQ0010495016	7417 HALL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Grease Blockage	7/10/2025	12:21	7/10/2025	12:22	0	Cleaned and Disinfected; Cleared Main Line
64221	WQ0010495003	1600 RIVER OAKS BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural failure	7/10/2025	13:29	7/10/2025	13:30	0	Cleaned and Disinfected
64224	WQ0010495016	8901 CRESTVIEW DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural failure	7/10/2025	15:53	7/10/2025	15:54	0	Set Bypass Pump



City of Houston - Houston Public Works
Monthly SSO Report
July 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64226	WQ0010495010	9827 LANEWELL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	7/11/2025	9:41	7/11/2025	9:42	0	Cleared City Clean Out; Cleaned and Disinfected
64227	WQ0010495023	6510 WAYSIDE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	7/11/2025	10:06	7/11/2025	10:07	0	Cleaned and Disinfected; Set Bypass Pump
64229	WQ0010495090	6518 FULTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural blockage	7/11/2025	11:31	7/11/2025	11:32	0	Set Bypass Pump
64233	WQ0010495110	15714 GATEBRIAR DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	7/11/2025	13:01	7/11/2025	13:02	0	Cleared City Clean Out; Cleaned and Disinfected
64236	WQ0010495110	15890 CLARKE SPRINGS DR	Storm Sewer (not contained)	Yes	1979	Manhole	Grease Blockage	7/12/2025	12:48	7/13/2025	21:47	1	Cleaned and Disinfected
64239	WQ0010495090	2322 MILLS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	7/13/2025	14:50	7/13/2025	14:51	0	Cleaned and Disinfected
64241	WQ0010495090	1622 CHIPPENDALE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	115	Service Lateral	Collection system structural failure	7/14/2025	10:07	7/14/2025	10:30	5	Set Bypass Pump; Cleaned and Disinfected
64242	WQ0010495090	1951 LAMAR ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Roots	7/14/2025	10:15	7/14/2025	10:16	0	Cleaned and Disinfected
64243	WQ0010495090	2011 MCKINNEY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	7/14/2025	11:50	7/14/2025	11:51	0	Cleared City Clean Out; Cleaned and Disinfected
64246	WQ0010495079	9933 TILTREE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/14/2025	16:50	7/14/2025	16:51	0	Cleaned and Disinfected; Set Bypass Pump
64252	WQ0010495090	1313 DENNIS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/15/2025	10:46	7/15/2025	10:47	0	Cleaned and Disinfected
64257	WQ0010495090	230 KING ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Grease Blockage	7/16/2025	9:03	7/16/2025	9:04	0	Cleared Main Line; Cleaned and Disinfected
64258	WQ0010495003	3520 SHEPHERD DR	Storm Sewer (not contained)	Yes	10899	Manhole	Grease Blockage	7/16/2025	8:44	7/18/2025	12:38	4	Cleared Main Line; Cleaned and Disinfected
64260	WQ0010495037	3802 TARTAN LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	10	Manhole	Collection system structural failure	7/16/2025	10:00	7/16/2025	10:10	1	Set Bypass Pump; Cleaned and Disinfected
64262	WQ0010495090	6820 UTAH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	7/16/2025	12:47	7/16/2025	12:48	0	Cleared City Clean Out; Cleaned and Disinfected
64266	WQ0010495003	14115 CANDLESHADE LN	Storm Sewer (not contained)	Yes	0	Service Lateral	Collection system structural failure	7/16/2025	17:44	7/16/2025	17:45	0	Cleaned and Disinfected
64271	WQ0010495003	6010 JAMES PL	Storm Sewer (not contained)	Yes	58	Manhole	Grease Blockage	7/17/2025	12:44	7/17/2025	14:40	0	Cleaned and Disinfected; Cleared Main Line
64273	WQ0010495090	7502 SHEPHERD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/17/2025	13:00	7/17/2025	13:01	0	Cleaned and Disinfected
64274	WQ0010495090	7315 GREENBRIAR DR	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	7/17/2025	13:21	7/17/2025	13:22	0	Cleared Main Line; Cleaned and Disinfected
64286	WQ0010495016	5202 MAYLE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	7/18/2025	13:25	7/18/2025	13:26	0	Cleared Main Line; Cleaned and Disinfected



City of Houston - Houston Public Works
Monthly SSO Report
July 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64292	WQ0010495077	12310 DORWAYNE CT	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	7/19/2025	14:20	7/19/2025	14:21	0	Cleaned and Disinfected; Set Bypass Pump
64295	WQ0010495090	1827 WIDDICOMB CT	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/20/2025	11:34	7/20/2025	11:35	0	Cleaned and Disinfected; Cleared City Clean Out
64300	WQ0010495090	3201 REID ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/21/2025	10:27	7/21/2025	10:28	0	Cleaned and Disinfected; Cleared Service Lateral
64302	WQ0010495099	7134 WOODSMAN TRL	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/21/2025	10:30	7/21/2025	10:31	0	Cleaned and Disinfected; Cleared Main Line
64305	WQ0010495002	2603 RIVERSIDE DR	Storm Sewer (not contained)	Yes	3738	Manhole	Grease Blockage	7/21/2025	13:56	7/22/2025	10:47	3	Cleared Main Line; Cleaned and Disinfected
64306	WQ0010495002	5330 KEYSTONE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/21/2025	14:26	7/21/2025	14:27	0	Cleaned and Disinfected
64308	WQ0010495002	7531 GLENHEATH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/21/2025	14:39	7/21/2025	14:40	0	Cleaned and Disinfected; Set Bypass Pump
64309	WQ0010495037	8006 DUNLAP ST	Storm Sewer (not contained)	Yes	3543	Private Cleanout	Grease Blockage	7/21/2025	15:16	7/22/2025	10:58	3	Cleared Main Line; Cleaned and Disinfected
64310	WQ0010495090	2327 CAMPBELL RD	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Rags/Wipes	7/21/2025	15:54	7/21/2025	15:55	0	Cleaned and Disinfected; Cleared City Clean Out
64314	WQ0010495099	7139 LUMBER JACK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/22/2025	11:19	7/22/2025	11:20	0	Cleaned and Disinfected; Cleared Main Line
64320	WQ0010495076	7710 LITTLE YORK RD	Storm Sewer (not contained)	Yes	2054	Manhole	Grease Blockage	7/22/2025	18:01	7/23/2025	11:08	2	Cleaned and Disinfected; Cleared Main Line
64321	WQ0010495037	5201 GULFTON ST	Storm Sewer (not contained)	Yes	236	City Cleanout	Rags/Wipes	7/22/2025	17:37	7/22/2025	21:33	1	Cleaned and Disinfected; Cleared City Clean Out
64322	WQ0010495030	1229 WISTERWOOD DR	Storm Sewer (not contained)	Yes	0	Private Cleanout	Grease Blockage	7/23/2025	9:11	7/23/2025	9:12	0	Cleared Main Line; Cleaned and Disinfected
64328	WQ0010495090	510 TIDWELL RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/23/2025	14:55	7/23/2025	14:56	0	Cleaned and Disinfected; Set Bypass Pump
64330	WQ0010495090	814 ENTERPRISE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/23/2025	14:40	7/23/2025	14:41	0	Cleaned and Disinfected
64331	WQ0010495090	1403 TABOR ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/23/2025	15:27	7/23/2025	15:28	0	Cleaned and Disinfected
64334	WQ0010495037	5214 BRAESVALLEY DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/24/2025	7:44	7/24/2025	7:45	0	Cleared City Clean Out; Cleaned and Disinfected
64335	WQ0010495037	8613 DAFFODIL ST	Bayou/surface water/drainage ditch	Yes	0	Private Cleanout	Grease Blockage	7/24/2025	8:21	7/24/2025	8:22	0	Cleared Main Line; Cleaned and Disinfected
64337	WQ0010495146	3403 MAPLE PARK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	3232	Manhole	Grease Blockage	7/24/2025	8:45	7/25/2025	11:41	2	Cleared Main Line; Cleaned and Disinfected
64340	WQ0010495090	8408 KNOX ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/24/2025	14:20	7/24/2025	14:21	0	Cleaned and Disinfected
64346	WQ0010495002	5519 WINDING CREEK WAY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	7/25/2025	10:01	7/25/2025	10:02	0	Cleaned and Disinfected; Cleared Main Line



City of Houston - Houston Public Works
Monthly SSO Report
July 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64348	WQ0010495002	5407 ORIOLE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/25/2025	11:42	7/25/2025	11:43	0	Cleaned and Disinfected; Cleared Main Line
64350	WQ0010495002	5819 DOOLITTLE BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/25/2025	12:31	7/25/2025	12:32	0	Cleaned and Disinfected
64352	WQ0010495077	13514 DULUTH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/25/2025	14:35	7/25/2025	14:36	0	Cleared City Clean Out; Cleaned and Disinfected
64353	WQ0010495075	10906 SAGETRAIL DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2754	Manhole	Grease Blockage	7/25/2025	14:50	7/26/2025	13:47	2	Cleared Main Line; Cleaned and Disinfected
64354	WQ0010495009	8243 ST LO RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	7/25/2025	15:03	7/25/2025	15:04	0	Cleaned and Disinfected; Cleared City Clean Out
64356	WQ0010495090	1208 MEADOW ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Roots	7/25/2025	17:24	7/25/2025	17:25	0	Cleared City Clean Out; Cleaned and Disinfected
64357	WQ0010495050	1218 MARLEEN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/26/2025	10:15	7/26/2025	10:16	0	Cleaned and Disinfected; Cleared Main Line
64361	WQ0010495090	8826 GLENHOUSE DR	Storm Sewer (not contained)	Yes	5130	Manhole	Grease Blockage	7/26/2025	16:50	7/28/2025	11:35	2	Cleaned and Disinfected; Set Bypass Pump
64362	WQ0010495037	6808 BINTLIFF DR	Storm Sewer - contained on site	No	800	Lift Station	Pump/Lift station instrumentation failure	7/26/2025	18:10	7/26/2025	18:50	20	Cleaned and Disinfected; Contain All or Portion of Spill
64363	WQ0010495037	6768 RENWICK DR	Storm Sewer (not contained)	Yes	732	Private Cleanout	Rags/Wipes	7/27/2025	7:32	7/27/2025	13:38	2	Cleared City Clean Out; Cleaned and Disinfected
64364	WQ0010495101	170 COUNTY FAIR DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	7/27/2025	1:20	7/27/2025	1:21	0	Cleaned and Disinfected; Set Bypass Pump
64365	WQ0010495002	6008 DEL RIO ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/27/2025	11:10	7/27/2025	11:11	0	Cleared Main Line; Cleaned and Disinfected
64366	WQ0010495003	5138 RIPPLEBROOK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/27/2025	11:10	7/27/2025	11:11	0	Cleared Private Line; Cleared Service Lateral; Cleaned and Disinfected
64377	WQ0010495090	622 26TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Roots	7/28/2025	13:58	7/28/2025	13:59	0	Cleared City Clean Out; Cleaned and Disinfected
64378	WQ0010495090	903 POLLARD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	7/28/2025	14:30	7/28/2025	14:31	0	Cleared City Clean Out; Cleaned and Disinfected
64382	WQ0010495090	801 WHITNEY ST	Bayou/surface water/drainage ditch	Yes	71.5	Gravity Main	Grease Blockage	7/28/2025	15:25	7/28/2025	17:48	0	Cleared Main Line; Cleaned and Disinfected
64389	WQ0010495003	219 GRAY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	6056	Manhole	Grease Blockage	7/29/2025	12:02	7/31/2025	14:30	2	Cleared Main Line; Cleaned and Disinfected
64391	WQ0010495090	602 10TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	7/29/2025	14:49	7/29/2025	14:50	0	Cleared City Clean Out; Cleaned and Disinfected
64393	WQ0010495002	2120 WALKER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	7/29/2025	15:38	7/29/2025	15:39	0	Cleared City Clean Out; Cleaned and Disinfected
64394	WQ0010495079	11415 KIRKWYN DR	Storm Sewer (not contained)	Yes	227	Manhole	Grease Blockage	7/29/2025	15:40	7/29/2025	19:27	1	Cleared Main Line; Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
July 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64395	WQ0010495016	6851 HOPPER RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	7/29/2025	16:18	7/29/2025	16:19	0	Cleared Main Line; Cleaned and Disinfected
64400	WQ0010495090	6522 GAINESVILLE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	7/30/2025	12:00	7/30/2025	12:01	0	Cleaned and Disinfected; Cleared City Clean Out
64401	WQ0010495023	6412 WAYSIDE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/30/2025	13:27	7/30/2025	13:28	0	Cleaned and Disinfected
64402	WQ0010495002	5934 SOUTHVILLE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	7/30/2025	14:14	7/30/2025	14:15	0	Cleaned and Disinfected
64404	WQ0010495077	1402 FEDERAL RD	Storm Sewer - contained on site	No	65.5	Private Cleanout	Grease Blockage	7/30/2025	16:15	7/30/2025	18:26	0	Cleaned and Disinfected; Cleared City Clean Out
64406	WQ0010495037	3802 TARTAN LN	Storm Sewer (not contained)	Yes	810	Manhole	Collection system structural failure	7/31/2025	7:55	7/31/2025	9:25	9	Cleaned and Disinfected; Set Bypass Pump
64407	WQ0010495090	4755 WESTHEIMER RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	22	Manhole	Grease Blockage	7/31/2025	8:32	7/31/2025	10:00	0	Cleared Service Lateral; Cleaned and Disinfected
64410	WQ0010495090	4319 CRAWFORD ST	Storm Sewer (not contained)	Yes	0	City Cleanout	Rags/Wipes	7/31/2025	14:53	7/31/2025	14:54	0	Cleared City Clean Out; Cleaned and Disinfected

Total Number of SSOs:	108
Number of Fish Kills Caused by SSOs:	0
Number of Notifications to the Public:	0
TWC § 7.251 Report Attached:	No

