



September 16, 2025

Associate Director, Water Enforcement
U.S. Environmental Protection Agency
Region VI
1201 Elm Street, Suite 500
Mail Code ECADW
Dallas, Texas 75270-2102

Via E-mail: Smalley.bryant@epa.gov

Re: City of Houston Wastewater Consent Decree
Civil Action No. 4:18-cv-03368
Monthly SSO Report – August 2025

Dear Mr. Smalley:

The City of Houston's monthly SSO summary report for August 2025 and corresponding SSO map are attached and provided in compliance with the requirements of Paragraph 61 of the City of Houston Wastewater Consent Decree.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

A digital signature of Phillip Goodwin, showing a stylized name in blue ink.

Phillip Goodwin

Senior Assistant Director
Houston Public Works, City of Houston

Enc. August 2025 Monthly SSO Report; SSO Map for August 2025
cc via email: Thomas Carroll, DOJ (Thomas.Carroll@usdoj.gov)
James Zimny, EPA (Zimny.james@epa.gov)
Alan Vaughn, EPA (vaughn.alan@epa.gov)
Brittany Wright, Texas AG's Office (Brittany.Wright@oag.texas.gov)
James Sallans, TCEQ (james.sallans@tceq.texas.gov)
Kristen Schlemmer, BCWK (kristen@bayoucitywaterkeeper.org)

PO Box 1562 | Houston, Texas 77251-1562 | HoustonPublicWorks.org

Capital Projects | Customer Account Services | Houston Permitting Center | Houston Water | Transportation & Drainage Operations



City of Houston - Houston Public Works
Monthly SSO Report
August 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64413	WQ0010495090	2419 GANO ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	8/1/2025	13:55	8/1/2025	13:56	0	Post Warning Signs; Cleaned and Disinfected
64414	WQ0010495002	6110 CULLEN BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system temporary blockage	8/1/2025	14:19	8/1/2025	14:20	0	Cleared City Clean Out; Cleaned and Disinfected
64426	WQ0010495016	7925 WAY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	8/4/2025	7:45	8/4/2025	7:46	0	Cleared City Clean Out; Cleaned and Disinfected
64433	WQ0010495002	7606 BELLFORT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	8/4/2025	15:17	8/4/2025	15:18	0	Cleared Main Line; Cleaned and Disinfected
64435	WQ0010495090	117 TURNER DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	8/5/2025	8:40	8/5/2025	8:41	0	Cleaned and Disinfected
64436	WQ0010495023	6119 BACHER ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Rags/Wipes	8/5/2025	8:53	8/5/2025	8:54	0	Cleared City Clean Out; Cleaned and Disinfected
64437	WQ0010495009	5105 WILMINGTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	8/5/2025	9:50	8/5/2025	9:51	0	Cleaned and Disinfected; Cleared City Clean Out
64438	WQ0010495002	5443 CROOKED CREEK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system temporary blockage	8/5/2025	10:40	8/5/2025	10:41	0	Cleaned and Disinfected; Cleared City Clean Out
64440	WQ0010495077	801 WESTMONT DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	8/5/2025	9:30	8/5/2025	9:31	0	Cleared Main Line; Cleaned and Disinfected
64442	WQ0010495090	3015 GREEN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	8/5/2025	11:30	8/5/2025	11:31	0	Cleared City Clean Out; Cleaned and Disinfected
64443	WQ0010495090	1034 DOLLY WRIGHT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	8/5/2025	15:45	8/5/2025	15:46	0	Cleared Service Lateral; Cleaned and Disinfected
64444	WQ0010495016	8634 HOMEWOOD LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	8/5/2025	17:13	8/5/2025	17:14	0	Cleaned and Disinfected; Cleared City Clean Out
64447	WQ0010495090	904 WESTHEIMER RD	Storm Sewer (not contained)	Yes	692	Private Sample Well	Grease Blockage	8/6/2025	9:57	8/6/2025	12:50	4	Cleared Main Line; Cleaned and Disinfected
64448	WQ0010495037	3802 TARTAN LN	Storm Sewer (not contained)	Yes	0	Manhole	Collection system structural failure	8/6/2025	11:34	8/6/2025	11:35	0	Cleaned and Disinfected
64452	WQ0010495076	1373 DEWALT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	8/6/2025	17:13	8/6/2025	17:14	0	Cleaned and Disinfected
64453	WQ0010495037	6000 GLENMONT DR	Storm Sewer (not contained)	Yes	935	Manhole	Grease Blockage	8/7/2025	7:43	8/7/2025	10:50	5	Cleared Main Line; Cleaned and Disinfected
64454	WQ0010495037	6030 GLENMONT DR	Storm Sewer (not contained)	Yes	935	City Cleanout	Grease Blockage	8/7/2025	7:43	8/7/2025	10:50	5	Cleared Main Line; Cleaned and Disinfected
64459	WQ0010495002	8447 PARK PLACE BLVD	Storm Sewer (not contained)	Yes	525	City Cleanout	Rags/Wipes	8/7/2025	11:51	8/7/2025	14:46	3	Cleared City Clean Out; Cleaned and Disinfected
64460	WQ0010495090	9618 MONA ST	Bayou/surface water/drainage ditch	Yes	0	Gravity Main	Rags/Wipes	8/7/2025	12:37	8/7/2025	12:38	0	Cleaned and Disinfected; Cleared Main Line
64464	WQ0010495110	16218 LAZY RIDGE RD	Within 5 ft. of Bayou/Surface Water/Drainage Ditch	Yes	288	Manhole	Grease Blockage	8/7/2025	16:37	8/7/2025	18:13	3	Cleared Main Line; Cleaned and Disinfected
64466	WQ0010495149	1521 HAMBLEEN RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	161	Gravity Main	Collection system structural blockage	8/8/2025	9:12	8/9/2025	11:23	0	Set Bypass Pump; Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
August 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64469	WQ0010495090	5101 BRADY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	8/8/2025	10:30	8/8/2025	10:31	0	Cleaned and Disinfected
64473	WQ0010495090	7521 CANAL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	8/8/2025	17:17	8/8/2025	17:18	0	Cleaned and Disinfected
64474	WQ0010495119	11503 SOUTHWEST FWY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	8/9/2025	8:14	8/9/2025	8:15	0	Cleared Main Line; Cleaned and Disinfected
64477	WQ0010495090	1439 WILLOW ROCK RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	8/9/2025	12:50	8/9/2025	12:51	0	Cleaned and Disinfected
64478	WQ0010495090	913 ELEANOR ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	8/10/2025	7:45	8/10/2025	7:46	0	Cleaned and Disinfected; Set Bypass Pump
64479	WQ0010495037	12226 BROOKVALLEY DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	8/10/2025	8:34	8/10/2025	8:35	0	Cleaned and Disinfected; Cleared City Clean Out
64481	WQ0010495119	11615 BROOKLEDGE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	8/10/2025	12:05	8/10/2025	12:06	0	Cleaned and Disinfected; Cleared City Clean Out
64489	WQ0010495076	6714 COVINGTON DR	Bayou/surface water/drainage ditch	Yes	165	Service Lateral	Grease Blockage	8/11/2025	10:27	8/11/2025	13:12	1	Cleared Main Line; Cleaned and Disinfected
64491	WQ0010495002	809 NUECES ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	8/11/2025	11:49	8/11/2025	11:50	0	Cleaned and Disinfected; Set Bypass Pump
64493	WQ0010495037	1131 UPTOWN PARK BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Rags/Wipes	8/11/2025	12:39	8/11/2025	12:40	0	Cleaned and Disinfected; Cleared Main Line
64494	WQ0010495016	7103 HAVERTON DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	8/11/2025	12:55	8/11/2025	12:56	0	Cleaned and Disinfected; Cleared Main Line
64501	WQ0010495090	8205 MONTRIDGE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Roots	8/11/2025	17:16	8/11/2025	17:17	0	Cleared City Clean Out; Cleaned and Disinfected
64502	WQ0010495002	3435 REEVES ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	8/11/2025	17:50	8/11/2025	17:51	0	Cleaned and Disinfected
64505	WQ0010495016	9241 HILLIS ST	Bayou/surface water/drainage ditch	Yes	9282	Service Lateral	Collection system structural failure	8/12/2025	9:56	8/14/2025	13:30	3	Set Bypass Pump
64506	WQ0010495090	5803 KIAM ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	8/12/2025	10:20	8/12/2025	10:21	0	Cleared Main Line; Cleaned and Disinfected
64507	WQ0010495090	602 WARNER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	8/12/2025	9:28	8/12/2025	9:29	0	Cleared Main Line; Cleaned and Disinfected
64512	WQ0010495110	15718 MUNSON LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	8/12/2025	11:56	8/12/2025	11:57	0	Cleared Main Line; Cleaned and Disinfected
64517	WQ0010495116	13118 ENSLEY WOOD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	8/13/2025	8:27	8/13/2025	8:28	0	Cleared City Clean Out; Cleaned and Disinfected
64518	WQ0010495037	6290 ROYALTON ST	Storm Sewer (not contained)	Yes	1981	Gravity Main	Grease Blockage	8/13/2025	7:47	8/13/2025	12:30	7	Cleared Main Line; Cleaned and Disinfected



City of Houston - Houston Public Works
Monthly SSO Report
August 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64520	WQ0010495090	7829 BALTIMORE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	8/13/2025	10:00	8/13/2025	10:01	0	Cleared City Clean Out; Cleaned and Disinfected
64522	WQ0010495090	2020 MANGUM RD	Storm Sewer (not contained)	Yes	0	Manhole	Rags/Wipes	8/13/2025	12:36	8/13/2025	12:37	0	Cleared Main Line; Cleaned and Disinfected
64523	WQ0010495002	7028 SAINT AUGUSTINE ST	Bayou/surface water/drainage ditch	Yes	15	City Cleanout	Grease Blockage	8/13/2025	13:42	8/14/2025	11:20	0	Cleared City Clean Out; Cleaned and Disinfected
64530	WQ0010495037	5454 LAMPASAS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	8/14/2025	14:51	8/14/2025	14:52	0	Cleaned and Disinfected
64531	WQ0010495090	8529 PANATELLA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural failure	8/14/2025	13:22	8/14/2025	13:23	0	Contain All or Portion of Spill
64533	WQ0010495003	2505 SHAKESPEARE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	8/15/2025	10:06	8/15/2025	10:07	0	Cleared City Clean Out; Cleaned and Disinfected
64538	WQ0010495002	8439 WIER DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	8/16/2025	12:57	8/16/2025	12:58	0	Cleared Service Lateral; Cleaned and Disinfected
64548	WQ0010495077	10901 GLORIA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	624	City Cleanout	Grease Blockage	8/19/2025	12:34	8/19/2025	16:02	3	Cleared City Clean Out; Cleaned and Disinfected
64549	WQ0010495002	7665 EDNA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	8/19/2025	12:22	8/19/2025	12:23	0	Cleaned and Disinfected; Cleared City Clean Out
64550	WQ0010495090	2722 COCHRAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	8/19/2025	13:00	8/19/2025	13:01	0	Cleared Main Line; Cleaned and Disinfected
64551	WQ0010495037	3754 TARTAN LN	Storm Sewer (not contained)	Yes	0	Manhole	Collection system structural failure	8/19/2025	13:46	8/19/2025	13:47	0	Cleaned and Disinfected
64560	WQ0010495076	7825 GROW LN	Storm Sewer (not contained)	Yes	90	Manhole	Grease Blockage	8/20/2025	10:47	8/20/2025	12:17	1	Cleared Main Line; Cleaned and Disinfected
64561	WQ0010495078	770 SAM HOUSTON PKWY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1050	Manhole	Grease Blockage	8/20/2025	13:50	8/20/2025	17:20	5	Cleared Main Line; Cleaned and Disinfected
64562	WQ0010495002	8225 FOUNTAIN ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Rags/Wipes	8/20/2025	11:20	8/20/2025	11:21	0	Cleaned and Disinfected; Cleared City Clean Out
64565	WQ0010495090	503 HOFFMAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	8/20/2025	14:38	8/20/2025	14:39	0	Cleaned and Disinfected; Cleared City Clean Out
64575	WQ0010495002	7133 KASSARINE PASS	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	8/22/2025	13:27	8/22/2025	13:28	0	Cleaned and Disinfected; Set Bypass Pump
64576	WQ0010495090	1201 SPRING ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system temporary blockage	8/23/2025	10:30	8/23/2025	10:31	0	Cleaned and Disinfected
64579	WQ0010495003	4210 HOWCHER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	8/23/2025	14:45	8/23/2025	14:46	0	Cleared City Clean Out; Cleaned and Disinfected
64580	WQ0010495037	6720 1/2 DE MOSS DR	Storm Sewer (not contained)	Yes	618	Manhole	Grease Blockage	8/24/2025	8:29	8/24/2025	13:38	2	Cleared Main Line; Cleaned and Disinfected
64581	WQ0010495090	5120 KARCHER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	8/24/2025	8:05	8/24/2025	8:06	0	Cleared City Clean Out; Cleaned and Disinfected
64582	WQ0010495002	2928 WOODRIDGE DR	Storm Sewer (not contained)	Yes	1480	Manhole	Grease Blockage	8/24/2025	10:40	8/24/2025	15:36	5	Cleared Main Line; Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
August 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64583	WQ0010495003	12813 ARP ST	Storm Sewer (not contained)	Yes	483.5	City Cleanout	Grease Blockage	8/24/2025	17:58	8/25/2025	10:05	0	Cleaned and Disinfected; Cleared Main Line
64589	WQ0010495030	2402 TRIWAY LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	8/25/2025	13:13	8/25/2025	13:14	0	Cleaned and Disinfected; Set Bypass Pump
64591	WQ0010495037	6000 BISSONNET ST	Bayou/surface water/drainage ditch	Yes	277	Manhole	Grease Blockage	8/25/2025	14:03	8/25/2025	18:40	1	Cleared Main Line; Cleaned and Disinfected
64594	WQ0010495090	4400 18TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	370	Private Cleanout	Rags/Wipes	8/25/2025	15:19	8/25/2025	18:24	2	Cleaned and Disinfected; Cleared Main Line
64600	WQ0010495077	3747 COLVIN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	8/26/2025	12:22	8/26/2025	12:23	0	Cleared City Clean Out; Cleaned and Disinfected
64601	WQ0010495050	8307 DELWIN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	8/26/2025	13:31	8/26/2025	13:32	0	Cleaned and Disinfected
64603	WQ0010495037	6000 BISSONNET ST	Storm Sewer (not contained)	Yes	1072	Manhole	Collection system temporary blockage	8/26/2025	17:38	8/27/2025	11:30	1	Cleaned and Disinfected; Set Bypass Pump; Cleared Main Line
64606	WQ0010495119	11502 CHARIOT DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	8/27/2025	9:31	8/27/2025	9:32	0	Cleared Main Line; Cleaned and Disinfected
64609	WQ0010495037	5302 JUDALON LN	Storm Sewer (not contained)	Yes	0	City Cleanout	Collection system structural failure	8/27/2025	12:23	8/27/2025	12:24	0	Cleared City Clean Out; Cleaned and Disinfected
64612	WQ0010495077	10901 GLORIA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	270	City Cleanout	Rags/Wipes	8/28/2025	8:30	8/28/2025	10:45	2	Cleared City Clean Out; Cleaned and Disinfected
64613	WQ0010495009	4907 TILI AND GILI ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	8/28/2025	8:34	8/28/2025	8:35	0	Cleaned and Disinfected
64618	WQ0010495075	11907 TEANECK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural blockage	8/28/2025	13:30	8/28/2025	13:31	0	Set Bypass Pump
64619	WQ0010495002	5950 PERSHING ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	8/28/2025	4:45	8/28/2025	4:46	0	Cleaned and Disinfected; Cleared Main Line
64621	WQ0010495016	8227 CRESTVIEW DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Grease Blockage	8/28/2025	16:00	8/28/2025	16:01	0	Cleared Main Line; Cleaned and Disinfected
64622	WQ0010495002	7172 VILLAGE WAY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	592	Manhole	Grease Blockage	8/24/2025	10:40	8/24/2025	15:36	2	Cleared Main Line; Cleaned and Disinfected
64626	WQ0010495090	1717 WEST ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	8/29/2025	9:30	8/29/2025	9:31	0	Set Bypass Pump; Cleaned and Disinfected
64634	WQ0010495111	3304 FOUNTAIN VIEW DR	Storm Sewer (not contained)	Yes	1423	Private Cleanout	Collection system structural blockage	8/30/2025	11:57	8/31/2025	11:40	1	Set Bypass Pump; Cleaned and Disinfected
64636	WQ0010495119	11421 BEECHNUT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	8/30/2025	15:12	8/30/2025	15:13	0	Cleaned and Disinfected
64638	WQ0010495016	9113 LANEWOOD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	8/31/2025	9:40	8/31/2025	9:41	0	Cleared City Clean Out; Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
August 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64639	WQ0010495009	5203 GREYLOG DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	8/31/2025	10:30	8/31/2025	10:31	0	Cleared Main Line; Cleaned and Disinfected
64641	WQ0010495003	2101 COLQUITT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	8/31/2025	13:33	8/31/2025	13:34	0	Cleared City Clean Out; Cleaned and Disinfected
64642	WQ0010495119	8620 BISSONNET ST	Storm Sewer (not contained)	Yes	9600	Force Main	Collection system structural failure	8/30/2025	15:00	9/1/2025	7:00	4	Cleaned and Disinfected

Total Number of SSOs:	83
Number of Fish Kills Caused by SSOs:	0
Number of Notifications to the Public:	0
TWC § 7.251 Report Attached:	No

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.

