



October 17, 2025

Associate Director, Water Enforcement
U.S. Environmental Protection Agency
Region VI
1201 Elm Street, Suite 500
Mail Code ECADW
Dallas, Texas 75270-2102

Via E-mail: Smalley.bryant@epa.gov


Re: City of Houston Wastewater Consent Decree
Civil Action No. 4:18-cv-03368
Monthly SSO Report – September 2025

Dear Mr. Smalley:

The City of Houston's monthly SSO summary report for September 2025 and corresponding SSO map are attached and provided in compliance with the requirements of Paragraph 61 of the City of Houston Wastewater Consent Decree.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

DocuSigned by:
Phillip Goodwin

Phillip Goodwin

Senior Assistant Director
Houston Public Works, City of Houston

Enc. September 2025 Monthly SSO Report; SSO Map for September 2025
cc via email: Thomas Carroll, DOJ (Thomas.Carroll@usdoj.gov)
James Zimny, EPA (Zimny.james@epa.gov)
Alan Vaughn, EPA (vaughn.alan@epa.gov)
Brittany Wright, Texas AG's Office (Brittany.Wright@oag.texas.gov)
James Sallans, TCEQ (james.sallans@tceq.texas.gov)
Kristen Schlemmer, BCWK (kristen@bayoucitywaterkeeper.org)

PO Box 1562 | Houston, Texas 77251-1562 | HoustonPublicWorks.org

Capital Projects | Customer Account Services | Houston Permitting Center | Houston Water | Transportation & Drainage Operations



City of Houston - Houston Public Works
Monthly SSO Report
September 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64644	WQ0010495077	10901 GLORIA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/1/2025	10:13	9/1/2025	10:14	0	Cleaned and Disinfected; Cleared Service Lateral
64645	WQ0010495075	11414 SAGEDOWNE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	WWTP Mechanical Failure	9/1/2025	10:27	9/1/2025	10:28	0	Cleaned and Disinfected
64650	WQ0010495090	1603 HEIGHTS BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/1/2025	13:41	9/1/2025	13:42	0	Cleaned and Disinfected
64655	WQ0010495016	8454 RINN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system temporary blockage	9/2/2025	9:38	9/2/2025	9:39	0	Cleaned and Disinfected
64656	WQ0010495009	8126 ROCKFORD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/2/2025	9:57	9/2/2025	9:58	0	Set Bypass Pump; Cleaned and Disinfected
64657	WQ0010495090	5429 LYNBROOK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/2/2025	9:34	9/2/2025	9:35	0	Set Bypass Pump; Cleaned and Disinfected
64660	WQ0010495002	8149 MILREDGE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	9/2/2025	13:16	9/2/2025	13:17	0	Cleaned and Disinfected
64662	WQ0010495002	7313 SANTIAGO ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/2/2025	14:15	9/2/2025	14:16	0	Cleaned and Disinfected; Cleared City Clean Out
64664	WQ0010495090	1201 SPRING ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system temporary blockage	9/2/2025	15:42	9/2/2025	15:43	0	Cleaned and Disinfected
64666	WQ0010495090	3023 MILAM ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/2/2025	16:50	9/2/2025	16:51	0	Cleared Main Line; Cleaned and Disinfected
64671	WQ0010495037	6818 HENDON LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/3/2025	8:53	9/3/2025	8:54	0	Cleared Main Line; Cleaned and Disinfected
64673	WQ0010495002	1919 BLODGETT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	9/3/2025	11:17	9/3/2025	11:18	0	Cleaned and Disinfected
64674	WQ0010495003	10510 CULLEN BLVD	Storm Sewer (not contained)	Yes	234	Manhole	Grease Blockage	9/3/2025	12:35	9/3/2025	16:29	1	Cleared Main Line; Cleared Private Line; Cleaned and Disinfected
64675	WQ0010495009	4929 ANGLETON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system structural failure	9/3/2025	11:30	9/3/2025	11:31	0	Cleaned and Disinfected
64676	WQ0010495002	1507 SMALLWOOD LN	Storm Sewer (not contained)	Yes	0	Private Sample Well	Collection system structural failure	9/3/2025	14:40	9/3/2025	14:41	0	Cleaned and Disinfected; Set Bypass Pump
64677	WQ0010495002	4530 KINGSBURY ST	Bayou/surface water/drainage ditch	Yes	0	Manhole	Grease Blockage	9/3/2025	16:06	9/3/2025	16:07	0	Cleaned and Disinfected
64683	WQ0010495002	3705 HUTCHINS ST	Storm Sewer (not contained)	Yes	0	Private Cleanout	Collection system structural failure	9/4/2025	10:17	9/4/2025	10:18	0	Set Bypass Pump; Cleaned and Disinfected
64688	WQ0010495002	3620 SOUTHMORE BLVD	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	9/4/2025	16:11	9/4/2025	16:12	0	Cleared Main Line; Cleaned and Disinfected
64690	WQ0010495090	1102 HAVNER LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/4/2025	16:40	9/4/2025	16:41	0	Cleaned and Disinfected; Cleared Main Line



City of Houston - Houston Public Works
Monthly SSO Report
September 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64691	WQ0010495090	3816 SEARLE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	9/4/2025	17:45	9/4/2025	17:46	0	Cleaned and Disinfected
64695	WQ0010495003	2038 NORTH BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural blockage	9/5/2025	14:04	9/5/2025	14:05	0	Set Bypass Pump; Contain All or Portion of Spill
64706	WQ0010495023	7018 DARIEN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/6/2025	8:05	9/6/2025	8:06	0	Cleaned and Disinfected; Cleared Service Lateral
64707	WQ0010495009	9418 COFFEE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	9/6/2025	8:21	9/6/2025	8:22	0	Cleared City Clean Out; Cleaned and Disinfected
64710	WQ0010495077	4527 MCCARTY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	9/6/2025	17:00	9/6/2025	17:01	0	Set Bypass Pump; Cleared Main Line; Cleaned and Disinfected
64713	WQ0010495090	7829 BALTIMORE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	9/6/2025	11:45	9/6/2025	11:46	0	Cleaned and Disinfected
64714	WQ0010495002	6430 BUFORD ST	Bayou/surface water/drainage ditch	Yes	0	Manhole	Grease Blockage	9/7/2025	9:00	9/7/2025	9:01	0	Cleared Main Line; Cleaned and Disinfected
64722	WQ0010495090	808 LAWRENCE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	9/8/2025	10:57	9/8/2025	10:58	0	Cleaned and Disinfected
64728	WQ0010495003	2238 TROON RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	9/8/2025	14:45	9/8/2025	14:46	0	Cleaned and Disinfected
64730	WQ0010495119	10215 FINCHWOOD LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Roots	9/8/2025	17:49	9/8/2025	17:50	0	Cleaned and Disinfected
64731	WQ0010495037	6818 HENDON LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	9/9/2025	8:18	9/9/2025	18:19	0	Cleared City Clean Out; Cleaned and Disinfected
64732	WQ0010495002	7550 DROUET ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/9/2025	9:04	9/9/2025	9:05	0	Cleaned and Disinfected
64738	WQ0010495037	6120 BELLAIRE BLVD	Storm Sewer (not contained)	Yes	730	Manhole	Grease Blockage	9/9/2025	17:41	9/9/2025	20:07	5	Cleared Main Line; Cleaned and Disinfected
64739	WQ0010495146	6323 SEVENLEAF LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system temporary blockage	9/10/2025	8:13	9/10/2025	8:14	0	Cleared Main Line; Cleaned and Disinfected
64744	WQ0010495146	4517 KINGWOOD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Pump/Lift Station Mechanical Failure	9/10/2025	14:55	9/10/2025	14:56	0	Cleaned and Disinfected
64759	WQ0010495090	5420 TILBURY DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Roots	9/11/2025	13:55	9/11/2025	13:56	0	Cleaned and Disinfected
64760	WQ0010495090	3422 VINTAGE ST	Bayou/surface water/drainage ditch	Yes	0	Service Lateral	Rags/Wipes	9/10/2025	18:55	9/10/2025	18:56	0	Cleaned and Disinfected; Cleared City Clean Out
64762	WQ0010495090	6935 AVENUE Q	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/11/2025	16:30	9/11/2025	16:31	0	Cleaned and Disinfected
64764	WQ0010495090	3718 YUPON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	9/11/2025	17:52	9/11/2025	17:53	0	Cleared Main Line; Cleaned and Disinfected
64768	WQ0010495078	633 RUSHCREEK DR	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	9/12/2025	10:18	9/12/2025	10:19	0	Cleaned and Disinfected; Cleared Main Line



City of Houston - Houston Public Works
Monthly SSO Report
September 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64770	WQ0010495077	4628 MCCARTY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system structural blockage	9/12/2025	11:33	9/12/2025	11:34	0	Cleared Main Line; Cleaned and Disinfected
64771	WQ0010495009	5738 WATERFORD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	9/12/2025	11:16	9/12/2025	11:17	0	Cleared Main Line; Cleaned and Disinfected
64789	WQ0010495002	6030 RIDGEWAY DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/15/2025	8:54	9/15/2025	8:55	0	Cleared City Clean Out; Cleaned and Disinfected
64790	WQ0010495037	12115 RENAISSANCE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	9/15/2025	10:17	9/15/2025	10:18	0	Cleaned and Disinfected; Cleared Service Lateral
64796	WQ0010495076	2405 DOLLY WRIGHT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	5629	Private Cleanout	Collection system structural failure	9/15/2025	13:45	9/19/2025	11:34	1	Set Bypass Pump; Cleaned and Disinfected
64798	WQ0010495090	6819 LYONS AVE	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/15/2025	15:07	9/15/2025	15:08	0	Cleared City Clean Out; Cleaned and Disinfected
64799	WQ0010495110	15714 GATEBRIAR DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/16/2025	8:31	9/16/2025	8:32	0	Cleared City Clean Out; Cleaned and Disinfected
64800	WQ0010495119	8604 BEECHNUT ST	Storm Sewer (not contained)	Yes	518	City Cleanout	Grease Blockage	9/16/2025	8:57	9/16/2025	13:16	2	Cleared City Clean Out; Cleaned and Disinfected
64801	WQ0010495090	3718 YUPON ST	Storm Sewer (not contained)	Yes	695	Manhole	Grease Blockage	9/16/2025	10:28	9/16/2025	15:06	2	Cleared Main Line; Cleaned and Disinfected
64809	WQ0010495077	12982 MYRTLE LN	Bayou/surface water/drainage ditch	Yes	634	City Cleanout	Grease Blockage	9/17/2025	12:58	9/17/2025	17:31	2	Cleared Main Line; Cleaned and Disinfected
64815	WQ0010495090	3422 VINTAGE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Grease Blockage	9/18/2025	13:50	9/18/2025	13:51	0	Cleaned and Disinfected; Cleared Main Line
64818	WQ0010495002	3448 DENNIS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	256	Private Cleanout	Collection system structural failure	9/19/2025	11:00	9/19/2025	13:08	2	Set Bypass Pump; Cleaned and Disinfected
64819	WQ0010495122	6605 RANKIN RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	9/19/2025	13:20	9/19/2025	13:21	0	Cleaned and Disinfected; Cleared Main Line
64822	WQ0010495116	12929 WESTPARK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Roots	9/20/2025	11:00	9/20/2025	11:01	0	Cleaned and Disinfected; Set Bypass Pump
64823	WQ0010495090	8638 FLOSSIE MAE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/19/2025	17:38	9/19/2025	17:39	0	Cleaned and Disinfected; Set Bypass Pump
64825	WQ0010495037	7655 MOONMIST DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Grease Blockage	9/20/2025	8:39	9/20/2025	8:40	0	Cleared Service Lateral; Cleaned and Disinfected
64828	WQ0010495009	6121 FUQUA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/20/2025	10:10	9/20/2025	10:11	0	Cleared City Clean Out; Cleaned and Disinfected
64830	WQ0010495016	7926 TALTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/20/2025	13:23	9/20/2025	13:24	0	Cleaned and Disinfected
64834	WQ0010495002	5215 CHENEVERT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	9/21/2025	8:02	9/21/2025	8:03	0	Cleaned and Disinfected



City of Houston - Houston Public Works
Monthly SSO Report
September 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64844	WQ0010495090	1131 CASTLEDALE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Grease Blockage	9/22/2025	11:39	9/22/2025	11:40	0	Cleaned and Disinfected; Cleared Main Line
64846	WQ0010495116	13118 ENSLEY WOOD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/22/2025	12:34	9/22/2025	12:35	0	Cleaned and Disinfected; Cleared City Clean Out
64847	WQ0010495030	3125 CRESTDALE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2202	Private Cleanout	Grease Blockage	9/22/2025	11:37	9/25/2025	13:00	1	Cleaned and Disinfected; Set Bypass Pump
64848	WQ0010495002	1111 OAK MEADOWS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/22/2025	15:49	9/22/2025	15:50	0	Cleaned and Disinfected; Cleared City Clean Out
64854	WQ0010495002	3522 TUAM ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/23/2025	14:11	9/23/2025	14:12	0	Cleaned and Disinfected
64855	WQ0010495030	10006 WESTVIEW DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/23/2025	14:00	9/23/2025	14:01	0	Cleared Main Line; Cleared City Clean Out; Cleaned and Disinfected
64856	WQ0010495002	1812 SEAGULL	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	9/23/2025	14:32	9/23/2025	14:33	0	Cleared Main Line; Cleaned and Disinfected
64857	WQ0010495090	5103 SHREVEPORT BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/23/2025	15:20	9/23/2025	15:21	0	Cleaned and Disinfected
64863	WQ0010495090	4400 18TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/24/2025	10:48	9/24/2025	10:49	0	Cleared Main Line; Cleaned and Disinfected
64873	WQ0010495090	4503 PECAN PARK CIR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/25/2025	10:11	9/25/2025	10:12	0	Cleared City Clean Out; Cleaned and Disinfected
64876	WQ0010495090	630 21ST ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/25/2025	11:19	9/25/2025	11:20	0	Cleaned and Disinfected; Set Bypass Pump
64879	WQ0010495076	8638 WILD BASIN DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/25/2025	13:20	9/25/2025	13:21	0	Cleared Main Line; Cleaned and Disinfected
64881	WQ0010495122	6605 RANKIN RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	9/25/2025	15:31	9/25/2025	15:32	0	Cleaned and Disinfected; Set Bypass Pump
64883	WQ0010495002	5627 DOULTON DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	9/26/2025	9:40	9/26/2025	9:41	0	Cleared City Clean Out; Cleaned and Disinfected
64884	WQ0010495090	6001 CLINTON DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/26/2025	10:26	9/26/2025	10:27	0	Set Bypass Pump; Cleaned and Disinfected
64885	WQ0010495023	8151 MILEY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	9/26/2025	10:55	9/26/2025	10:56	0	Cleared Main Line; Cleaned and Disinfected
64886	WQ0010495076	6661 LIMESTONE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	9/26/2025	10:40	9/26/2025	10:41	0	Cleared Main Line; Cleaned and Disinfected
64887	WQ0010495090	6808 AVENUE Q	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/26/2025	12:01	9/26/2025	12:02	0	Cleaned and Disinfected; Set Bypass Pump

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
Monthly SSO Report
September 2025

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64889	WQ0010495090	733 DRENNAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural failure	9/26/2025	12:44	9/26/2025	12:45	0	Cleaned and Disinfected
64890	WQ0010495111	11106 CONCHO ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	9/26/2025	11:51	9/26/2025	11:52	0	Cleared Main Line; Cleaned and Disinfected
64891	WQ0010495119	8002 GESSNER RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/26/2025	14:15	9/26/2025	14:16	0	Cleaned and Disinfected; Set Bypass Pump; Cleared City Clean Out
64892	WQ0010495002	6422 SLOAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/26/2025	14:55	9/26/2025	14:56	0	Cleared Main Line; Cleaned and Disinfected
64897	WQ0010495076	7710 LITTLE YORK RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	6875	Manhole	Grease Blockage	9/27/2025	12:05	9/28/2025	11:00	5	Cleared City Clean Out; Cleaned and Disinfected
64902	WQ0010495003	11102 HUNKLER DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/28/2025	9:20	9/28/2025	9:21	0	Cleaned and Disinfected; Set Bypass Pump
64903	WQ0010495037	5926 WARM SPRINGS RD	Storm Sewer (not contained)	Yes	172	Manhole	Grease Blockage	9/28/2025	10:03	9/28/2025	12:55	1	Cleared Main Line; Cleaned and Disinfected
64909	WQ0010495076	3402 BLALOCK RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	176	Manhole	Rags/Wipes	9/29/2025	11:01	9/29/2025	13:57	1	Cleaned and Disinfected; Cleared Main Line
64910	WQ0010495037	12303 FAIRMEADOW DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	9/29/2025	12:01	9/29/2025	12:02	0	Set Bypass Pump; Cleaned and Disinfected
64911	WQ0010495002	3522 TUAM ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Rags/Wipes	9/29/2025	12:13	9/29/2025	12:14	0	Cleared City Clean Out; Cleaned and Disinfected
64912	WQ0010495076	6661 LIMESTONE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	9/29/2025	12:35	9/29/2025	12:36	0	Cleared Main Line; Cleaned and Disinfected
64913	WQ0010495076	8453 RAYSON RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	9/29/2025	15:16	9/29/2025	15:17	0	Set Bypass Pump; Cleaned and Disinfected
64914	WQ0010495002	908 ALTIC ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/29/2025	15:34	9/29/2025	15:35	0	Cleared City Clean Out; Cleaned and Disinfected
64918	WQ0010495090	2401 NOTTINGHAM ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	9/30/2025	13:54	9/30/2025	13:55	0	Cleaned and Disinfected
64919	WQ0010495076	5416 DEEP FOREST DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	9/30/2025	12:55	9/30/2025	12:56	0	Set Bypass Pump; Cleaned and Disinfected
64920	WQ0010495090	515 COLUMBIA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	332	Gravity Main	Collection system structural failure	9/30/2025	15:13	9/30/2025	17:59	2	Cleaned and Disinfected; Set Bypass Pump



SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
64921	WQ0010495077	12929 SAMUEL LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	9/30/2025	15:24	9/30/2025	15:25	0	Cleared Main Line; Cleaned and Disinfected
64922	WQ0010495016	8837 KELLETT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	9/30/2025	16:30	9/30/2025	16:31	0	Cleaned and Disinfected

Total Number of SSOs:	94
Number of Fish Kills Caused by SSOs:	0
Number of Notifications to the Public:	0
TWC § 7.251 Report Attached:	No

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.

